

# Quick Reference Guide


## Premier Elite Series

INS222-10

CE

**Texecom**

# Quick Start Guide



## Installation Sequence

Before attempting to install the alarm system, read this section. Once you have an overall understanding of the installation sequence, carefully work through each step.

### 1: Design the Layout

Make a rough sketch of the premises to get an idea of where the alarm detection devices, keypads, zone expanders etc. are to be located.

### 2: Mounting the Panel

The control panel should be mounted in a dry area close to an unswitched AC power source and the incoming telephone line (if using a communicator). Mount the control panel on a flat, plumb wall using at least three screws of appropriate size.

**NOTE** You must complete all wiring before connecting the battery or applying AC mains to the control panel.

**WARNING: ELECTRICITY CAN KILL BEFORE connecting the control panel ALWAYS disconnect the supply at the consumer unit. If in ANY doubt consult a qualified electrician.**

**IMPORTANT SAFETY INFORMATION. HAZARDOUS VOLTAGES INSIDE, NO USER SERVICEABLE PARTS, NO USER ACCESS.**

**ONLY** connect the mains supply to the mains terminal block, NEVER connect the mains supply directly to the PCB.

ALWAYS refer to National Wiring Regulations when conducting installation.

An appropriate and readily accessible disconnection device (e.g. an unswitched fused spur) MUST be provided as part of the installation.

The disconnection device must NOT be fitted in a flexible cord.

Where identification of the neutral in the mains supply is NOT possible a two-pole disconnection device MUST be used.

Use mains cable of adequate carrying capacity for the rated current (i.e. at least 0.75mm<sup>2</sup>).

### 3: Install the Keypads and Zone Expanders

Mount and connect the keypads, zone expanders and output modules to the control panel (see page 3).

### 4: Install the Alarm Detection Devices

Install the detection devices, PIR's, Contacts, PA Buttons etc. and connect them to the control panel (see page 4).

### 5: Install the External Sounder

Install the external sounder and connect to the control panel.

### 6: Other Wiring

Complete all other wiring including speakers, telephone line and output connections etc..

### 7: Applying Power to the Control Panel

Once steps 1 to 6 are completed, power can be applied to the control panel.

When applying power for the first time, the factory default settings must be loaded. Hold down the Load Defaults then apply power. Power should always be connected in the following order:

- Connect the red battery lead to the positive terminal of the battery and then connect the black battery lead to the negative terminal

**NOTE** The panel will only become 'live' when the AC Mains is connected or the 'Battery Kick-start' button is pressed.

- Connect the AC mains



### 8: Keypad messages

The keypad may show a mix of faults following first power up and go into alarm. If the system goes into alarm, **enter the default Engineer code ① ② ③ ④**, and the alarm tone will stop. To access the Engineer Programming Menu, **enter the default Engineer code ① ② ③ ④**

### 9: Select Language & Country Code

Immediately following power up you will be prompted to select the panel language and country code. The country code determines the panel defaults loaded and the operation of the system.

## 10: Confirm Devices

The "Confirm Devices" menu will appear check and make sure all installed Keypads and Expanders are showing, press  and  again to confirm.

## 11: Learn & Place Ricochet Devices

Once the panel is powered up you will be prompted to learn any Ricochet devices to the system. Devices should be learnt local to the receiver, and placed in their selected locations starting with the one closest to the receiver.

# Wiring & Addressing Network Devices

## Connecting Devices to the Network

Before connecting keypads, zone expanders and output modules, isolate ALL power from the control panel (AC Mains & Battery). Do not continue if there is still power present on the control panel.



*Connecting devices with power still present on the control panel may damage the device or control panel and invalidate any warranty.*

Keypads, expanders and output modules are all connected to the network terminals located at the bottom left hand corner of the control panel PCB, and may be connected serially (daisy chain), in parallel (star) or any combination of the two



*No more than 8 zone expanders, 8 keypads and 4 output modules can be connected to each network. The maximum number of devices that can be connected in total will depend on the control panel fitted.*

## Wiring the Network

The networks are made up of four terminals incorporating power and data. To ensure correct operation, all four terminals on the device must be connected to the corresponding terminals on the control panel, or previous device

Terminal	Description
+	+12V Supply
-	0V Supply
T	Transmit Data
R	Receive Data

Devices can be connected using 4-core cable. However, it is recommended that 6 or 8-core cable is used as the spare cores can be used to 'Double Up' on the power connections if needed.

**Stranded tinned annealed copper BS4737 7/0.2 alarm cable can be used for most installations. However, under certain conditions it may be necessary to use screened cable of the same specification.**

**PLEASE NOTE. The conductor resistance should be no greater than 8Ω per 100metres.**

**The usage of Low grade TCCA (tinned copper clad cable) can have a detrimental effect on the operation of the system and the cable distances specified in this manual.**

## Cable Distances

The maximum recommended distance for devices when using standard 7/0.2 alarm cable is:

- 250m for each branch when using the star (parallel) configuration
- When using a daisy chain (series) configuration the maximum distance will depend on the number of devices connected on the chain. Whichever method of wiring configuration is used, ensure that the voltage between the '+' and '-' terminals at each device is no lower than 10.0V when the system is running on the standby battery.
- Wireless expanders/panels should be mounted at least 50cm away from metallic surfaces.

## 12: Programming the Control Panel

Please refer to section 5 for instruction on programming the control panel.

## 13: Testing the System

Test the system thoroughly to ensure that all features and functions operate as required (see page 19 for details).

Configuration	Max. Cable Run
1. Keypad + 2 PIR's @15mA	250m
2. Expander + 2 PIR's @15mA	250m
3. Expander + 8 PIR's @15mA	100m
4. As No. 3 + 16Ω Speaker	30m

## Keypad Addressing

Each keypad must be assigned a different address using the DIL switches located on the left hand side of the PCB.

Address	DIL 1	DIL 2	DIL 3	DIL 4	
1	On or off	Off	Off	Off	
2	Off	On	Off	Off	
3	Off	Off	On	Off	
4	Off	Off	Off	On	
5 *	On	Off	Off	On	
6 *	Off	On	Off	On	
7 *	Off	Off	On	On	
8 *	On	Off	On	On	
Engineers	On	On	On	On	



*Never set two keypads on the same network to the same address.*

*When using a keypad as an Engineer's keypad, the DIL switches must all be 'On'.*

*\* 88 168 & 640 only*

## Expander Addressing

Each Expander must be assigned a different address using the DIL switches located in the centre of the PCB. The table below shows the expander addressing:

Address	DIL 1	DIL 2	DIL 3	DIL 4	
1*	On or off	Off	Off	Off	
2*	Off	On	Off	Off	
3**	Off	Off	On	Off	
4**	Off	Off	Off	On	
5***	On	Off	Off	On	
6***	Off	On	Off	On	
7***	Off	Off	On	On	
8***	On	Off	On	On	



*Never set two expanders on the same network to the same address.*

*\* 24/48/64/88/168/640*

*\*\* 48/64/88/168/640 only*

*\*\*\* 88 168 & 640 only*


# Wiring Zones

## Wiring Types

Terminal types are shown below.

12/12-W/24/24-W/48/48-W/64-W

48/88/168/Keypads & 8XP Expander




Any zones that are not being used must be linked out or programmed as 'Not Used' (see page 6).

When using End Of Line wiring, only 1 device should normally be connected to each zone.

A zone short can be programmed for 'Active' or 'Tamper' response (see page 9).

### End Of Line (EOL) All panels


Use this wiring configuration when connecting normally closed detection devices to the zone using 2-Wires. Zone wiring should be programmed as Double Pole/EOL (see page 6)



**NOTE** When using this configuration, no more than 3 detectors can be connected to each zone.

### Premier Elite 48/88/168 & 640 Double Pole


Use this wiring configuration when connecting normally closed or normally open detection devices to the zone using 4-Wires. Zone wiring should be programmed as Double Pole/EOL (see page 6)



**NOTE** When using this configuration, no more than 10 detectors can be connected to each zone.

### Triple End Of Line (TEOL)

Use this wiring configuration when connecting PIR devices with that require Anti Mask and Fault detection. Several zone wiring programming options are available for this, Triple EOL is illustrated below(see page 6).




**NOTE** When using this configuration, only 1 detector can be connected to each zone.

**NOTE** Alternative resistor values are available.

### Normally Open Or Normally Closed Circuits

This wiring configuration is normally used for key switches with a N/O or N/C contact. Zone wiring options are provided for each.



### Testing Zones

To test zones prior to commissioning, use the **View Zone Status** option in **Engineers Utilities** see page 19. You must exit engineers mode to apply any changes to zone resistance monitoring.

# Programming Guide

## Introduction

The **Premier Elite** range of control panels are all programmed using a simple menu based system. The LCD keypad information displayed for each option is question based. Simple use of the (Yes)/✓ & (No)/✗ keys allows you to accept or alter the information presented to you, whilst the ⬆ key allows you to navigate through all of the main and sub menus.

The menu structure is split into 9 main headings, each with sub menus. The following sections detail all of the main menu headings and all options available within the sub menus. Where applicable any shortcut keys have been described.

Comprehensive flow diagrams and full descriptions of all available options and functions are detailed in INS176 Premier Elite Installation Manual, available on the enclosed CD or from our website.


## Default Codes

Default Engineer Code (00)	1234
Default User Code (01)	5678


0	Log Off Engineer
✓/Yes	Press ✓/Yes to log out of the Engineer Programming menu

## Main Menu

### Top Line Menu Structure




# 1 Zone Setup



1 Zone Setup																																																													
[checkmark]/[Yes]	<p><b>Zone Types</b></p> <p>Use 1 - 8 to enter zone number, [X]/[No] to edit, 0 - 9 or [up/down] to select a zone type, [checkmark]/[Yes] to accept</p> <table border="0"> <tr> <td>0</td><td>Not Used</td><td>[up/down]</td><td>Medical</td><td>[up/down]</td><td>Conf PA audible</td> </tr> <tr> <td>1</td><td>Entry/Exit 1</td><td>[up/down]</td><td>24Hr Gas</td><td>[up/down]</td><td>Conf PA silent</td> </tr> <tr> <td>2</td><td>Entry/Exit 2</td><td>[up/down]</td><td>Auxiliary</td><td></td><td></td> </tr> <tr> <td>3</td><td>Guard</td><td>[up/down]</td><td>Tamper</td><td></td><td></td> </tr> <tr> <td>4</td><td>Guard Access</td><td>[up/down]</td><td>Exit Terminator</td><td></td><td></td> </tr> <tr> <td>5</td><td>24Hr Audible</td><td>[up/down]</td><td>Moment Key</td><td></td><td></td> </tr> <tr> <td>6</td><td>24Hr Silent</td><td>[up/down]</td><td>Latching Key</td><td></td><td></td> </tr> <tr> <td>7</td><td>PA Audible</td><td>[up/down]</td><td>Security</td><td></td><td></td> </tr> <tr> <td>8</td><td>PA Silent</td><td>[up/down]</td><td>Omit Key</td><td></td><td></td> </tr> <tr> <td>9</td><td>Fire</td><td>[up/down]</td><td>Custom</td><td></td><td></td> </tr> </table>	0	Not Used	[up/down]	Medical	[up/down]	Conf PA audible	1	Entry/Exit 1	[up/down]	24Hr Gas	[up/down]	Conf PA silent	2	Entry/Exit 2	[up/down]	Auxiliary			3	Guard	[up/down]	Tamper			4	Guard Access	[up/down]	Exit Terminator			5	24Hr Audible	[up/down]	Moment Key			6	24Hr Silent	[up/down]	Latching Key			7	PA Audible	[up/down]	Security			8	PA Silent	[up/down]	Omit Key			9	Fire	[up/down]	Custom		
0	Not Used	[up/down]	Medical	[up/down]	Conf PA audible																																																								
1	Entry/Exit 1	[up/down]	24Hr Gas	[up/down]	Conf PA silent																																																								
2	Entry/Exit 2	[up/down]	Auxiliary																																																										
3	Guard	[up/down]	Tamper																																																										
4	Guard Access	[up/down]	Exit Terminator																																																										
5	24Hr Audible	[up/down]	Moment Key																																																										
6	24Hr Silent	[up/down]	Latching Key																																																										
7	PA Audible	[up/down]	Security																																																										
8	PA Silent	[up/down]	Omit Key																																																										
9	Fire	[up/down]	Custom																																																										
[checkmark]/[Yes]	<p><b>Zone Attributes 1</b></p> <p>Press [X]/[No] to edit, 1 - 8 to select an attribute, [checkmark]/[Yes] to accept</p> <table border="0"> <tr> <td>1</td><td>O = Omittable</td><td>5</td><td>3 = Part 3 Omit</td> </tr> <tr> <td>2</td><td>F = Force Omit</td><td>6</td><td>A = Access</td> </tr> <tr> <td>3</td><td>1 = Part 1 Omit</td><td>7</td><td>E = Entry/Exit 2</td> </tr> <tr> <td>4</td><td>2 = Part 2 Omit</td><td>8</td><td>G = Guard</td> </tr> </table>	1	O = Omittable	5	3 = Part 3 Omit	2	F = Force Omit	6	A = Access	3	1 = Part 1 Omit	7	E = Entry/Exit 2	4	2 = Part 2 Omit	8	G = Guard																																												
1	O = Omittable	5	3 = Part 3 Omit																																																										
2	F = Force Omit	6	A = Access																																																										
3	1 = Part 1 Omit	7	E = Entry/Exit 2																																																										
4	2 = Part 2 Omit	8	G = Guard																																																										
[checkmark]/[Yes]	<p><b>Zone Attributes 2</b></p> <p>Press [X]/[No] to edit, 1 - 8 to select an attribute, [checkmark]/[Yes] to accept</p> <table border="0"> <tr> <td>1</td><td>D = Double Knock</td><td>1</td><td>R = Reset</td> </tr> <tr> <td>2</td><td>B = Beam Pair</td><td>6</td><td>A = Auto Re-arm</td> </tr> <tr> <td>3</td><td>S = Soak Test</td><td>7</td><td>Q = Quick Resp.</td> </tr> <tr> <td>4</td><td>F = Activity</td><td>8</td><td>E = Eng. Alarm</td> </tr> </table>	1	D = Double Knock	1	R = Reset	2	B = Beam Pair	6	A = Auto Re-arm	3	S = Soak Test	7	Q = Quick Resp.	4	F = Activity	8	E = Eng. Alarm																																												
1	D = Double Knock	1	R = Reset																																																										
2	B = Beam Pair	6	A = Auto Re-arm																																																										
3	S = Soak Test	7	Q = Quick Resp.																																																										
4	F = Activity	8	E = Eng. Alarm																																																										
[checkmark]/[Yes]	<p><b>Key Attributes</b> <i>(only applicable for keyswitch zone types)</i></p> <p>Press [X]/[No] to edit, 1 - 8 to select an attribute, [checkmark]/[Yes] to accept</p> <table border="0"> <tr> <td>1</td><td>I = Instant Arming</td><td>5</td><td>S = Silent Arming</td> </tr> <tr> <td>2</td><td>P = Part Arming</td><td>6</td><td>T = Time Arm Disable</td> </tr> <tr> <td>3</td><td>F = Full Disable</td><td>7</td><td>K = Key Tube (Monitor Only)</td> </tr> <tr> <td>4</td><td>D = Disarm Only</td><td>8</td><td>L = Log Only in Arm (Monitor Only when armed)</td> </tr> </table>	1	I = Instant Arming	5	S = Silent Arming	2	P = Part Arming	6	T = Time Arm Disable	3	F = Full Disable	7	K = Key Tube (Monitor Only)	4	D = Disarm Only	8	L = Log Only in Arm (Monitor Only when armed)																																												
1	I = Instant Arming	5	S = Silent Arming																																																										
2	P = Part Arming	6	T = Time Arm Disable																																																										
3	F = Full Disable	7	K = Key Tube (Monitor Only)																																																										
4	D = Disarm Only	8	L = Log Only in Arm (Monitor Only when armed)																																																										
[checkmark]/[Yes]	<p><b>Custom Zones (Zone Response 1)</b> <i>(only applicable for custom zone types)</i></p> <p>Press [X]/[No] to edit, 1 - 8 to select an attribute, [checkmark]/[Yes] to accept</p> <table border="0"> <tr> <td>1</td><td>B = Bell/Strobe</td><td>4</td><td>C = Enable Comms</td> </tr> <tr> <td>2</td><td>I = Internals</td><td>5</td><td>W = Warning</td> </tr> <tr> <td>3</td><td>M = Monitor 24Hr</td><td></td><td></td> </tr> </table>	1	B = Bell/Strobe	4	C = Enable Comms	2	I = Internals	5	W = Warning	3	M = Monitor 24Hr																																																		
1	B = Bell/Strobe	4	C = Enable Comms																																																										
2	I = Internals	5	W = Warning																																																										
3	M = Monitor 24Hr																																																												

1	Zone Setup	
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Custom Attributes (Zone Response 2)</b> <i>(only applicable for custom zone types)</i>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to edit, <b>1 - 8</b> to select an attribute, <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept <b>1</b> S* = Seismic Zone <b>4</b> D* = Seismic Debug <b>2</b> R* = Seismic Reference <b>3</b> T* = Seismic Twin * For future use
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Areas 12/24/48/64/88/168</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to edit, <b>1 - 8</b> to select an area, <b>0</b> = all areas, <input checked="" type="checkbox"/> / <input type="checkbox"/> Area = areas A - H and I - P), <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept.
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Areas 640</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to edit, <input checked="" type="checkbox"/> / <input type="checkbox"/> Chime or <input checked="" type="checkbox"/> / <input type="checkbox"/> Part to select an area group (1-4), use <input checked="" type="checkbox"/> / <input type="checkbox"/> Area to select areas A - H and I - P), <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept.
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Text</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to edit, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described below), <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept <b>1</b> . , ? ! 1 @ " - <b>6</b> M N O 6 <input checked="" type="checkbox"/> / <input type="checkbox"/> Move Cursor <b>2</b> A B C 2 <b>7</b> P Q R S <input checked="" type="checkbox"/> / <input type="checkbox"/> Chime Copy Text to Memory <b>3</b> D E F 3 <b>8</b> T U V 8 <input checked="" type="checkbox"/> / <input type="checkbox"/> Part Paste Text from Memory <b>4</b> G H I 4 <b>9</b> W X Y Z <input checked="" type="checkbox"/> / <input type="checkbox"/> No Upper, Lower Case, Predictive Text and Numerical <b>5</b> J K L 5 <b>0</b> 0 _
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Chime</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to alter chime tone, <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to go to the next option.
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes		<input checked="" type="checkbox"/> / <input type="checkbox"/> No Silent <input checked="" type="checkbox"/> / <input type="checkbox"/> No Chime 1 <input checked="" type="checkbox"/> / <input type="checkbox"/> No Chime 2 <input checked="" type="checkbox"/> / <input type="checkbox"/> No Chime 3
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Test</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to alter Test option, <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to go to the next option.
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Wiring</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to alter wiring type, <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept <b>0</b> Normally Open <b>3</b> Triple EOL <b>6</b> 2K2/4K7/(6K8) <b>1</b> Normally Closed <b>4</b> 1K/1K/(3K) <b>7</b> 4K7/4K7 <b>2</b> Double Pole EOL <b>5</b> 4K7/6K8(12K) <b>8</b> WD Monitor
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Zone Group</b>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to alter Zone Group, <b>1 - 8</b> to select a group <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept Elite12 & 24= 2 Groups, Elite 48/64 = 4 Groups, Elite 88 = 8 Groups, Elite 168 = 16 Groups, Elite 640= 64 Groups
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Ricochet® learn</b>	Use <b>0 - 9</b> or <input checked="" type="checkbox"/> / <input type="checkbox"/> to select the zone, <input checked="" type="checkbox"/> / <input type="checkbox"/> No or <input checked="" type="checkbox"/> / <input type="checkbox"/> Reset to start the learn process, (20s) <input checked="" type="checkbox"/> / <input type="checkbox"/> No then <input checked="" type="checkbox"/> / <input type="checkbox"/> Reset to delete a device.
<input checked="" type="checkbox"/> / <input type="checkbox"/> Yes	<b>Ricochet Device Type**</b> <i>(only available when a Ricochet device is learned to the zone)</i>	Press <input checked="" type="checkbox"/> / <input type="checkbox"/> No to alter Ricochet device type, <input checked="" type="checkbox"/> / <input type="checkbox"/> Yes to accept <b>0</b> Always Awake <b>4</b> Expander O/P 3-4* <b>8</b> Expander O/P 4-6* <b>1</b> Hybrid <b>5</b> Expander O/P 5-6* <b>9</b> Device Specific <b>2</b> Auto <b>6</b> Expander O/P 7-8* <input checked="" type="checkbox"/> / <input type="checkbox"/> Exp O/P 1,2,3,4,5,6,7 & 8 <b>3</b> Expander O/P 1-2* <b>7</b> Expander O/P 1-3*
** Reserved for future use ** Changing the default Ricochet® device type can have a detrimental impact on battery life.		

## 2 Area Programming




2 Area Programming																
0	<p><b>Timers</b></p> <p>Use <b>↕</b> to select an area, <b>✓/Yes</b> to select a timer, <b>0 - 9</b> to enter a value, <b>✓/Yes</b> to accept</p> <table border="0" style="width: 100%;"> <tr> <td>1: Exit Delay for Areas:</td> <td>6: Bell Duration for Areas:</td> </tr> <tr> <td>2: Entry Delay 1 for Areas:</td> <td>7: Coms Delay for Areas:</td> </tr> <tr> <td>3: Entry Delay 2 for Areas:</td> <td>8: Part Bell Delay for Areas:</td> </tr> <tr> <td>4: 2<sup>nd</sup> Entry Delay for Areas:</td> <td>9: Confirmed PA Timer for Areas:</td> </tr> <tr> <td>5: Bell Delay for Areas:</td> <td></td> </tr> </table>	1: Exit Delay for Areas:	6: Bell Duration for Areas:	2: Entry Delay 1 for Areas:	7: Coms Delay for Areas:	3: Entry Delay 2 for Areas:	8: Part Bell Delay for Areas:	4: 2 <sup>nd</sup> Entry Delay for Areas:	9: Confirmed PA Timer for Areas:	5: Bell Delay for Areas:						
1: Exit Delay for Areas:	6: Bell Duration for Areas:															
2: Entry Delay 1 for Areas:	7: Coms Delay for Areas:															
3: Entry Delay 2 for Areas:	8: Part Bell Delay for Areas:															
4: 2 <sup>nd</sup> Entry Delay for Areas:	9: Confirmed PA Timer for Areas:															
5: Bell Delay for Areas:																
1	<p><b>Arming Modes</b></p> <p>Use <b>↕</b> to select an area, <b>1 - 5</b> to select arming an mode, <b>✓/Yes</b> to accept</p> <table border="0" style="width: 100%;"> <tr> <td>1 Entry/Exit</td> <td>4 Instant</td> </tr> <tr> <td>2 Exit Term.</td> <td>5 Deferred</td> </tr> <tr> <td>3 Timed Exit</td> <td></td> </tr> </table>	1 Entry/Exit	4 Instant	2 Exit Term.	5 Deferred	3 Timed Exit										
1 Entry/Exit	4 Instant															
2 Exit Term.	5 Deferred															
3 Timed Exit																
2	<p><b>Area Arm Suites</b> 12/24/48/64/88/168</p> <p>Use <b>↕</b> to select a suite, <b>X/No</b> no to edit, <b>1 - 8</b> to select an area, <b>0</b> = all areas, <b>Area</b> = areas A - H and I - P), <b>✓/Yes</b> to accept</p>															
2	<p><b>Area Arm Suites 640</b></p> <p>Use <b>↕</b> to select a suite, <b>X/No</b> no to edit, <b>Chime</b> - <b>Part</b> to select an area group (1-4), use <b>Area</b> to select areas A - H and I - P), <b>✓/Yes</b> to accept.</p>															
3	<p><b>Area Suite Text</b></p> <p>Use <b>1 - 8</b> to select a suite, <b>X/No</b> to edit, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described below), <b>✓/Yes</b> to accept</p> <table border="0" style="width: 100%;"> <tr> <td>1 . , ? ! 1 @ " -</td> <td>6 M N O 6</td> <td>↕ Move Cursor</td> </tr> <tr> <td>2 A B C 2</td> <td>7 P Q R S 7</td> <td>Chime Copy Text to Memory</td> </tr> <tr> <td>3 D E F 3</td> <td>8 T U V 8</td> <td>Part Paste Text from Memory</td> </tr> <tr> <td>4 G H I 4</td> <td>9 W X Y Z 9</td> <td>X/No Upper, Lower Case, Predictive Text &amp; Numerical</td> </tr> <tr> <td>5 J K L 5</td> <td>0 0 _</td> <td></td> </tr> </table>	1 . , ? ! 1 @ " -	6 M N O 6	↕ Move Cursor	2 A B C 2	7 P Q R S 7	Chime Copy Text to Memory	3 D E F 3	8 T U V 8	Part Paste Text from Memory	4 G H I 4	9 W X Y Z 9	X/No Upper, Lower Case, Predictive Text & Numerical	5 J K L 5	0 0 _	
1 . , ? ! 1 @ " -	6 M N O 6	↕ Move Cursor														
2 A B C 2	7 P Q R S 7	Chime Copy Text to Memory														
3 D E F 3	8 T U V 8	Part Paste Text from Memory														
4 G H I 4	9 W X Y Z 9	X/No Upper, Lower Case, Predictive Text & Numerical														
5 J K L 5	0 0 _															
4	<p><b>Suite Arm Mode</b></p> <p>Use <b>↕</b> to select an area, <b>1 - 5</b> to select an arming mode, <b>✓/Yes</b> to accept</p> <table border="0" style="width: 100%;"> <tr> <td>1 Entry/Exit</td> <td>4 Instant</td> </tr> <tr> <td>2 Exit Term.</td> <td>5 Deferred</td> </tr> <tr> <td>3 Timed Exit</td> <td></td> </tr> </table>	1 Entry/Exit	4 Instant	2 Exit Term.	5 Deferred	3 Timed Exit										
1 Entry/Exit	4 Instant															
2 Exit Term.	5 Deferred															
3 Timed Exit																
5	<p><b>Area Options</b> 12/24/48/88/168</p> <p>Use <b>↕</b> to select an option, <b>X/No</b> to edit, <b>1 - 8</b> to select an area, <b>0</b> = all areas, <b>Area</b> = areas A - H and I - P), <b>✓/Yes</b> to accept</p> <p>640</p>															



2 Area Programming																																									
2	<p>Use <b>↔</b> to select an option, <b>X</b>/<b>No</b> no to edit, <b>♪</b>/<b>Chime</b> - <b>🏠</b>/<b>Part</b> to select an area group (1-4), use <b>🏠</b>/<b>Area</b> to select areas A – H and I –P), <b>✓</b>/<b>Yes</b> to accept.</p> <table border="0"> <tr> <td>00: Auto Part Arm</td> <td>20: Unarm Fire Coms</td> </tr> <tr> <td>01: Part Arm Instant</td> <td>21: Unarm Tamper Coms</td> </tr> <tr> <td>02: Part Arm Silent</td> <td>22: Auto Arm Areas</td> </tr> <tr> <td>03: Remote Arm</td> <td>23: Area A Foyer</td> </tr> <tr> <td>04: Remote Disarm</td> <td>24: Log Part Omits</td> </tr> <tr> <td>05: Panel Tamper</td> <td>25: Multi Knock Area</td> </tr> <tr> <td>06: Bell Tamper</td> <td>26: UDL Keypad</td> </tr> <tr> <td>07: Auxiliary Tampe/Fault</td> <td>27: Auto Chime (C2A)</td> </tr> <tr> <td>08: Panel Speaker</td> <td>28: Confirm in Entry</td> </tr> <tr> <td>09: Bell &amp; Strobe op</td> <td>29: Conf. After Entry</td> </tr> <tr> <td>10: Alarm Eng Reset</td> <td>30: Enable Part Arms</td> </tr> <tr> <td>11: Confirmation Reset</td> <td>31: Bell Squawk</td> </tr> <tr> <td>12: Tamper Eng Reset</td> <td>32: Fob After Entry</td> </tr> <tr> <td>13: Anti-code Reset</td> <td>33: Armed = Coms</td> </tr> <tr> <td>14: Phone Line Fault</td> <td>34: 2-Wire Smoke</td> </tr> <tr> <td>15: Arm With L/Fault</td> <td>35: Fault Eng Reset</td> </tr> <tr> <td>16: AC Mains Fail</td> <td>36: L/Fault Eng Rst</td> </tr> <tr> <td>17: Arm With AC Fail</td> <td>37: AC Fail Eng Rst</td> </tr> <tr> <td>18: Full Arm Coms</td> <td>38: Anti-Masking When Armed</td> </tr> <tr> <td>19: Part Arm Coms</td> <td>39: No Arming Before</td> </tr> </table>	00: Auto Part Arm	20: Unarm Fire Coms	01: Part Arm Instant	21: Unarm Tamper Coms	02: Part Arm Silent	22: Auto Arm Areas	03: Remote Arm	23: Area A Foyer	04: Remote Disarm	24: Log Part Omits	05: Panel Tamper	25: Multi Knock Area	06: Bell Tamper	26: UDL Keypad	07: Auxiliary Tampe/Fault	27: Auto Chime (C2A)	08: Panel Speaker	28: Confirm in Entry	09: Bell & Strobe op	29: Conf. After Entry	10: Alarm Eng Reset	30: Enable Part Arms	11: Confirmation Reset	31: Bell Squawk	12: Tamper Eng Reset	32: Fob After Entry	13: Anti-code Reset	33: Armed = Coms	14: Phone Line Fault	34: 2-Wire Smoke	15: Arm With L/Fault	35: Fault Eng Reset	16: AC Mains Fail	36: L/Fault Eng Rst	17: Arm With AC Fail	37: AC Fail Eng Rst	18: Full Arm Coms	38: Anti-Masking When Armed	19: Part Arm Coms	39: No Arming Before
00: Auto Part Arm	20: Unarm Fire Coms																																								
01: Part Arm Instant	21: Unarm Tamper Coms																																								
02: Part Arm Silent	22: Auto Arm Areas																																								
03: Remote Arm	23: Area A Foyer																																								
04: Remote Disarm	24: Log Part Omits																																								
05: Panel Tamper	25: Multi Knock Area																																								
06: Bell Tamper	26: UDL Keypad																																								
07: Auxiliary Tampe/Fault	27: Auto Chime (C2A)																																								
08: Panel Speaker	28: Confirm in Entry																																								
09: Bell & Strobe op	29: Conf. After Entry																																								
10: Alarm Eng Reset	30: Enable Part Arms																																								
11: Confirmation Reset	31: Bell Squawk																																								
12: Tamper Eng Reset	32: Fob After Entry																																								
13: Anti-code Reset	33: Armed = Coms																																								
14: Phone Line Fault	34: 2-Wire Smoke																																								
15: Arm With L/Fault	35: Fault Eng Reset																																								
16: AC Mains Fail	36: L/Fault Eng Rst																																								
17: Arm With AC Fail	37: AC Fail Eng Rst																																								
18: Full Arm Coms	38: Anti-Masking When Armed																																								
19: Part Arm Coms	39: No Arming Before																																								
6	<p><b>Time Arm Areas</b></p> <p>Use <b>↔</b> to select an area, <b>✓</b>/<b>Yes</b> to toggle between the arm and disarm timer, <b>1</b> - <b>8</b> to select timers.</p>																																								
7	<p><b>Area Text</b></p> <p>Use <b>↔</b> to select an area, <b>X</b>/<b>No</b> to edit, <b>0</b> - <b>9</b> to select characters (press the required key the appropriate number of times), <b>✓</b>/<b>Yes</b> to accept</p>																																								


### 3 Global Options



3 Global Options																																																																
0	<p><b>System Timers</b></p> <p>Use <b>↕</b> to select a timer, press <b>X/No</b> and then <b>0 - 9</b> to enter a value, <b>✓/Yes</b> to accept</p> <table border="0"> <tr> <td>00: Exit Settle Time</td> <td>13: Pulse Period 3</td> <td>26: Confirmation Dly</td> </tr> <tr> <td>01: Global Bell Dly.</td> <td>14: Line Fault Delay</td> <td>27: Warning Delay</td> </tr> <tr> <td>02: Global Bell Dur.</td> <td>15: AC Off Delay</td> <td>28: Keypad Lock Time</td> </tr> <tr> <td>03: Double Knock Dly</td> <td>16: Batt Test Period</td> <td>29: Eng. Log Off Dly</td> </tr> <tr> <td>04: Beam Pair Time</td> <td>17: Batt Test Time</td> <td>30: Fire Bell Delay</td> </tr> <tr> <td>05: Activity Delay</td> <td>18: Soak Test Time</td> <td>31: Forced Entry Dly</td> </tr> <tr> <td>06: Abort Delay</td> <td>19: Service Interval</td> <td>32: Supervision Time</td> </tr> <tr> <td>07: Courtesy Time</td> <td>20: Test Call Every</td> <td>33: Poll IP Every</td> </tr> <tr> <td>08: Defer Arming By</td> <td>21: Min Random Time</td> <td>34: Confirmed PA Timer</td> </tr> <tr> <td>09: Auto Arm Delay</td> <td>22: Max Random Time</td> <td>35: Seismic Timer 1*</td> </tr> <tr> <td>10: Menu Time Out</td> <td>23: Door Strike Time</td> <td>36: Seismic Timer 2*</td> </tr> <tr> <td>11: Pulse Period 1</td> <td>24: Zone Response</td> <td>37: Seismic Timer 3*</td> </tr> <tr> <td>12: Pulse Period 2</td> <td>25: Keypad PA Delay</td> <td>*for future use</td> </tr> </table>	00: Exit Settle Time	13: Pulse Period 3	26: Confirmation Dly	01: Global Bell Dly.	14: Line Fault Delay	27: Warning Delay	02: Global Bell Dur.	15: AC Off Delay	28: Keypad Lock Time	03: Double Knock Dly	16: Batt Test Period	29: Eng. Log Off Dly	04: Beam Pair Time	17: Batt Test Time	30: Fire Bell Delay	05: Activity Delay	18: Soak Test Time	31: Forced Entry Dly	06: Abort Delay	19: Service Interval	32: Supervision Time	07: Courtesy Time	20: Test Call Every	33: Poll IP Every	08: Defer Arming By	21: Min Random Time	34: Confirmed PA Timer	09: Auto Arm Delay	22: Max Random Time	35: Seismic Timer 1*	10: Menu Time Out	23: Door Strike Time	36: Seismic Timer 2*	11: Pulse Period 1	24: Zone Response	37: Seismic Timer 3*	12: Pulse Period 2	25: Keypad PA Delay	*for future use																								
00: Exit Settle Time	13: Pulse Period 3	26: Confirmation Dly																																																														
01: Global Bell Dly.	14: Line Fault Delay	27: Warning Delay																																																														
02: Global Bell Dur.	15: AC Off Delay	28: Keypad Lock Time																																																														
03: Double Knock Dly	16: Batt Test Period	29: Eng. Log Off Dly																																																														
04: Beam Pair Time	17: Batt Test Time	30: Fire Bell Delay																																																														
05: Activity Delay	18: Soak Test Time	31: Forced Entry Dly																																																														
06: Abort Delay	19: Service Interval	32: Supervision Time																																																														
07: Courtesy Time	20: Test Call Every	33: Poll IP Every																																																														
08: Defer Arming By	21: Min Random Time	34: Confirmed PA Timer																																																														
09: Auto Arm Delay	22: Max Random Time	35: Seismic Timer 1*																																																														
10: Menu Time Out	23: Door Strike Time	36: Seismic Timer 2*																																																														
11: Pulse Period 1	24: Zone Response	37: Seismic Timer 3*																																																														
12: Pulse Period 2	25: Keypad PA Delay	*for future use																																																														
1	<p><b>System Config.</b></p> <p>Use <b>↕</b> to select an option, <b>X/No</b> to change the option, <b>✓/Yes</b> to move to next option.</p> <table border="0"> <tr> <td>00: No Bell on Arm Fail</td> <td>21: Zone Shorted = Tamper</td> <td>42: Cable Cut Expander Tamper</td> </tr> <tr> <td>01: Bell is an SAB</td> <td>22: Remote Reset = Reset</td> <td>43: Soak Test Active Arm Indication</td> </tr> <tr> <td>02: Clock is 24Hr</td> <td>23: User Code Outputs Pulse</td> <td>44: Confirm Low fob battery on Arm</td> </tr> <tr> <td>03: Auto BST/GMT Time Change</td> <td>24: Test Calls Timed</td> <td>45: Entry Stray Notification</td> </tr> <tr> <td>04: View Armed Areas</td> <td>25: Battery Test by Timer</td> <td>46: BS Entry Stray Notification</td> </tr> <tr> <td>05: Global Bell Time</td> <td>26: Bells on 1<sup>st</sup> Alarm</td> <td>47: No Confirm for Alarm Device Tamper</td> </tr> <tr> <td>06: 24Hr Omit Local</td> <td>27: Internal Sounders on 1<sup>st</sup> Alarm</td> <td>48: Two Stage Wireless Arming</td> </tr> <tr> <td>07: Remove Omits</td> <td>28: Confirmation on Arm</td> <td>49: Stage Two with Zone OR Keypad</td> </tr> <tr> <td>08: Override Communicator Delay</td> <td>29: Aborted Alarms = Engineer Reset</td> <td>50: Confirmed Hold Up 2 Active PA Zones</td> </tr> <tr> <td>09: NVM is Unlocked</td> <td>30: Auto AV Outputs</td> <td>51: Max Log Messages 3</td> </tr> <tr> <td>10: User + Engineer</td> <td>31: System Clock = 50Hz</td> <td>52: Code Entry Timed</td> </tr> <tr> <td>11: Chime Audible</td> <td>32: 80 Column Printer</td> <td>53: PD6662:2010</td> </tr> <tr> <td>12: Allow Omitting of Tampers</td> <td>33: Disable Text</td> <td>54: Auxiliary Input = Tamper</td> </tr> <tr> <td>13: Enable Online Printing</td> <td>34: Enable EN50131-1 Requirements</td> <td>55: Part Arm Squawk</td> </tr> <tr> <td>14: Hide Activity Faults</td> <td>35: First Alarm after Entry Timeout = Confirmed</td> <td>56: No Display Open Zones</td> </tr> <tr> <td>15: Hide Exit Errors</td> <td>36: Global Keypad Information</td> <td>57: Disable Battery Replacement Mode</td> </tr> <tr> <td>16: Code Tampers Alarm</td> <td>37: EN50131-1 Grade 2 System</td> <td>58: Remote Arming Instant</td> </tr> <tr> <td>17: Code Tampers Lockout Keypad</td> <td>38: Disable Radio FOB PA</td> <td></td> </tr> <tr> <td>18: Areas are displayed as A-H, I-P</td> <td>39: Armed Mask = Fault</td> <td></td> </tr> <tr> <td>19: Auto Select of Areas</td> <td>40: Radio FOB PA is Silent</td> <td></td> </tr> <tr> <td>20: Enable Predictive Text</td> <td>41: Enable PSU Battery Monitoring</td> <td></td> </tr> </table>	00: No Bell on Arm Fail	21: Zone Shorted = Tamper	42: Cable Cut Expander Tamper	01: Bell is an SAB	22: Remote Reset = Reset	43: Soak Test Active Arm Indication	02: Clock is 24Hr	23: User Code Outputs Pulse	44: Confirm Low fob battery on Arm	03: Auto BST/GMT Time Change	24: Test Calls Timed	45: Entry Stray Notification	04: View Armed Areas	25: Battery Test by Timer	46: BS Entry Stray Notification	05: Global Bell Time	26: Bells on 1 <sup>st</sup> Alarm	47: No Confirm for Alarm Device Tamper	06: 24Hr Omit Local	27: Internal Sounders on 1 <sup>st</sup> Alarm	48: Two Stage Wireless Arming	07: Remove Omits	28: Confirmation on Arm	49: Stage Two with Zone OR Keypad	08: Override Communicator Delay	29: Aborted Alarms = Engineer Reset	50: Confirmed Hold Up 2 Active PA Zones	09: NVM is Unlocked	30: Auto AV Outputs	51: Max Log Messages 3	10: User + Engineer	31: System Clock = 50Hz	52: Code Entry Timed	11: Chime Audible	32: 80 Column Printer	53: PD6662:2010	12: Allow Omitting of Tampers	33: Disable Text	54: Auxiliary Input = Tamper	13: Enable Online Printing	34: Enable EN50131-1 Requirements	55: Part Arm Squawk	14: Hide Activity Faults	35: First Alarm after Entry Timeout = Confirmed	56: No Display Open Zones	15: Hide Exit Errors	36: Global Keypad Information	57: Disable Battery Replacement Mode	16: Code Tampers Alarm	37: EN50131-1 Grade 2 System	58: Remote Arming Instant	17: Code Tampers Lockout Keypad	38: Disable Radio FOB PA		18: Areas are displayed as A-H, I-P	39: Armed Mask = Fault		19: Auto Select of Areas	40: Radio FOB PA is Silent		20: Enable Predictive Text	41: Enable PSU Battery Monitoring	
00: No Bell on Arm Fail	21: Zone Shorted = Tamper	42: Cable Cut Expander Tamper																																																														
01: Bell is an SAB	22: Remote Reset = Reset	43: Soak Test Active Arm Indication																																																														
02: Clock is 24Hr	23: User Code Outputs Pulse	44: Confirm Low fob battery on Arm																																																														
03: Auto BST/GMT Time Change	24: Test Calls Timed	45: Entry Stray Notification																																																														
04: View Armed Areas	25: Battery Test by Timer	46: BS Entry Stray Notification																																																														
05: Global Bell Time	26: Bells on 1 <sup>st</sup> Alarm	47: No Confirm for Alarm Device Tamper																																																														
06: 24Hr Omit Local	27: Internal Sounders on 1 <sup>st</sup> Alarm	48: Two Stage Wireless Arming																																																														
07: Remove Omits	28: Confirmation on Arm	49: Stage Two with Zone OR Keypad																																																														
08: Override Communicator Delay	29: Aborted Alarms = Engineer Reset	50: Confirmed Hold Up 2 Active PA Zones																																																														
09: NVM is Unlocked	30: Auto AV Outputs	51: Max Log Messages 3																																																														
10: User + Engineer	31: System Clock = 50Hz	52: Code Entry Timed																																																														
11: Chime Audible	32: 80 Column Printer	53: PD6662:2010																																																														
12: Allow Omitting of Tampers	33: Disable Text	54: Auxiliary Input = Tamper																																																														
13: Enable Online Printing	34: Enable EN50131-1 Requirements	55: Part Arm Squawk																																																														
14: Hide Activity Faults	35: First Alarm after Entry Timeout = Confirmed	56: No Display Open Zones																																																														
15: Hide Exit Errors	36: Global Keypad Information	57: Disable Battery Replacement Mode																																																														
16: Code Tampers Alarm	37: EN50131-1 Grade 2 System	58: Remote Arming Instant																																																														
17: Code Tampers Lockout Keypad	38: Disable Radio FOB PA																																																															
18: Areas are displayed as A-H, I-P	39: Armed Mask = Fault																																																															
19: Auto Select of Areas	40: Radio FOB PA is Silent																																																															
20: Enable Predictive Text	41: Enable PSU Battery Monitoring																																																															
2	<p><b>System Options</b></p> <p>Use <b>↕</b> to select a timer, press <b>X/No</b> and then <b>0 - 9</b> to enter a value, <b>✓/Yes</b> to accept</p> <table border="0"> <tr> <td>0: Advisory Volume</td> <td>4: Multiple Knocks</td> <td>8: Language</td> </tr> <tr> <td>1: Chime Volume</td> <td>5: Adjust Clock</td> <td>9: Country Code &amp; Defaults</td> </tr> <tr> <td>2: Number Of Re-Arms</td> <td>6: Quick Count</td> <td></td> </tr> <tr> <td>3: Anti-code Resets</td> <td>7: Modem Level</td> <td></td> </tr> </table>	0: Advisory Volume	4: Multiple Knocks	8: Language	1: Chime Volume	5: Adjust Clock	9: Country Code & Defaults	2: Number Of Re-Arms	6: Quick Count		3: Anti-code Resets	7: Modem Level																																																				
0: Advisory Volume	4: Multiple Knocks	8: Language																																																														
1: Chime Volume	5: Adjust Clock	9: Country Code & Defaults																																																														
2: Number Of Re-Arms	6: Quick Count																																																															
3: Anti-code Resets	7: Modem Level																																																															
3	<p><b>Monitor Hardware</b></p> <p>Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change the option, <b>✓/Yes</b> to accept</p> <table border="0"> <tr> <td>1 P = Line Fault</td> <td>4 B = Bell Tamper</td> <td>7 B = Battery Faults</td> </tr> <tr> <td>2 A = AC Power Failure</td> <td>5 A = Aux Tamper</td> <td></td> </tr> <tr> <td>3 O = O/Ps/Chgr</td> <td>6 L = Panel Lid Tamper</td> <td></td> </tr> </table>	1 P = Line Fault	4 B = Bell Tamper	7 B = Battery Faults	2 A = AC Power Failure	5 A = Aux Tamper		3 O = O/Ps/Chgr	6 L = Panel Lid Tamper																																																							
1 P = Line Fault	4 B = Bell Tamper	7 B = Battery Faults																																																														
2 A = AC Power Failure	5 A = Aux Tamper																																																															
3 O = O/Ps/Chgr	6 L = Panel Lid Tamper																																																															
4	<p><b>Control Timers</b></p> <p>Use <b>↕</b> to select an area, <b>0 - 9</b> to enter the 1<sup>st</sup> On time, <b>✓/Yes</b> to accept</p> <p>Use <b>1 - 7</b> to select the 1<sup>st</sup> On time days of operation, <b>✓/Yes</b> to accept</p> <p>Use <b>0 - 9</b> to enter the 1<sup>st</sup> Off time, <b>✓/Yes</b> to accept</p> <p>Use <b>1 - 7</b> to select the 1<sup>st</sup> Off time days of operation, <b>✓/Yes</b> to accept</p>																																																															
5	<p><b>System Text</b></p> <p>Use <b>↕</b> to select a message, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described previously), <b>✓/Yes</b> to accept</p>																																																															
6	<p><b>Part Arm Text</b></p> <p>Use <b>↕</b> to select a Part Arm, <b>X/No</b> to edit the Part Arm text, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described previously), <b>✓/Yes</b> to accept</p>																																																															


3 Global Options		
7	Holiday Dates	Use <b>↕</b> to select a holiday date, <b>0 - 9</b> to enter the required date ( <b>D D M M Y Y</b> ), <b>✓/Yes</b> to accept
8	Speaker Tones	Use <b>↕</b> to select a tone type, <b>X/No</b> to turn the tone on/off, <b>✓/Yes</b> to accept
9	PC Output Text	Use <b>↕</b> to select an Output, <b>X/No</b> to edit, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described previously), <b>✓/Yes</b> to accept
↕	Custom O/P Text	Use <b>↕</b> to select an Output, <b>X/No</b> to edit, <b>0 - 9</b> to select characters (predictive text is on by default but may be turned off as described previously), <b>✓/Yes</b> to accept

## 4 Keypad Setup




4 Keypad Setup										
✓/Yes	Areas 12/24/48/64/88/168	Use <b>1 - 8</b> to select keypad, <b>0</b> to select network, <b>X/No</b> to edit, <b>1 - 8</b> to select an area, <b>0</b> = all areas, <b>Area</b> = areas A - H and I - P), <b>✓/Yes</b> to accept								
✓/Yes	Areas 640	Use <b>1 - 8</b> to select keypad, <b>0</b> to select network, <b>X/No</b> to edit, <b>Chime</b> - <b>Part</b> to select an area group (1-4), use <b>Area</b> to select areas A - H and I - P), <b>✓/Yes</b> to accept.								
✓/Yes	Zone Mapping	Press <b>X/No</b> to edit, <b>1 - 8</b> to enter zone number, <b>✓/Yes</b> to move to 2 <sup>nd</sup> zone, press <b>,</b> <b>✓/Yes</b> to accept changes.								
✓/Yes	Options	Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change the option, <b>✓/Yes</b> to accept <table border="0" style="width: 100%;"> <tr> <td><b>1</b> P = PA Enabled</td> <td><b>5</b> A = PA is Audible</td> </tr> <tr> <td><b>2</b> F = Fire Enabled</td> <td><b>6</b> D = PA is Delayed</td> </tr> <tr> <td><b>3</b> F = Medical Enabled</td> <td><b>7</b> Q = Quick Arm On</td> </tr> <tr> <td><b>4</b> T = Tamper Enabled</td> <td><b>8</b> O = Info.LED&gt;Output</td> </tr> </table>	<b>1</b> P = PA Enabled	<b>5</b> A = PA is Audible	<b>2</b> F = Fire Enabled	<b>6</b> D = PA is Delayed	<b>3</b> F = Medical Enabled	<b>7</b> Q = Quick Arm On	<b>4</b> T = Tamper Enabled	<b>8</b> O = Info.LED>Output
<b>1</b> P = PA Enabled	<b>5</b> A = PA is Audible									
<b>2</b> F = Fire Enabled	<b>6</b> D = PA is Delayed									
<b>3</b> F = Medical Enabled	<b>7</b> Q = Quick Arm On									
<b>4</b> T = Tamper Enabled	<b>8</b> O = Info.LED>Output									
✓/Yes	Volume	Press <b>X/No</b> to edit, <b>0 - 8</b> to enter a value, <b>✓/Yes</b> to accept								
✓/Yes	Sounder Options	Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change the option, <b>✓/Yes</b> to accept <table border="0" style="width: 100%;"> <tr> <td><b>1</b> F = Fire Tones Enabled</td> <td><b>5</b> E = Entry Tones Enabled</td> </tr> <tr> <td><b>2</b> A = Alarm Tones Enabled</td> <td><b>6</b> X = Exit Tones Enabled</td> </tr> <tr> <td><b>3</b> F = Fault Tones Enabled</td> <td><b>7</b> C = Chime Tones Enabled</td> </tr> <tr> <td><b>4</b> S = Service Tones Enabled</td> <td><b>8</b> K = Use Keypad Areas</td> </tr> </table>	<b>1</b> F = Fire Tones Enabled	<b>5</b> E = Entry Tones Enabled	<b>2</b> A = Alarm Tones Enabled	<b>6</b> X = Exit Tones Enabled	<b>3</b> F = Fault Tones Enabled	<b>7</b> C = Chime Tones Enabled	<b>4</b> S = Service Tones Enabled	<b>8</b> K = Use Keypad Areas
<b>1</b> F = Fire Tones Enabled	<b>5</b> E = Entry Tones Enabled									
<b>2</b> A = Alarm Tones Enabled	<b>6</b> X = Exit Tones Enabled									
<b>3</b> F = Fault Tones Enabled	<b>7</b> C = Chime Tones Enabled									
<b>4</b> S = Service Tones Enabled	<b>8</b> K = Use Keypad Areas									

# 5 Expander Setup



5 Expander Setup																
checkmark/Yes	<b>Areas</b> 12/24/48/64/88/168 Use 1 - 8 to select expander, 0 to select network, X/No to edit, 1 - 8 to select an area, (0 = all areas, Area = areas A - H and I - P), checkmark/Yes to accept															
checkmark/Yes	<b>Areas 640</b> Use 1 - 8 to select expander, 0 to select network, X/No to edit, Chime - Part to select an area group (1-4), use Area to select areas A - H and I - P), checkmark/Yes to accept.															
checkmark/Yes	<b>Text</b> Press X/No to edit text, 0 - 9 to select characters (predictive text is on by default but may be altered as described below), checkmark/Yes to accept <table border="0" style="width: 100%;"> <tr> <td>1 .,?!1@ "-</td> <td>6 M N O 6</td> <td>Move Cursor</td> </tr> <tr> <td>2 A B C 2</td> <td>7 P Q R S 7</td> <td>Chime Copy Text to Memory</td> </tr> <tr> <td>3 D E F 3</td> <td>8 T U V 8</td> <td>Part Paste Text from Memory</td> </tr> <tr> <td>4 G H I 4</td> <td>9 W X Y Z 9</td> <td>X/No Upper, Lower Case, Predictive Text &amp; Numerical</td> </tr> <tr> <td>5 J K L 5</td> <td>0 0 _</td> <td></td> </tr> </table>	1 .,?!1@ "-	6 M N O 6	Move Cursor	2 A B C 2	7 P Q R S 7	Chime Copy Text to Memory	3 D E F 3	8 T U V 8	Part Paste Text from Memory	4 G H I 4	9 W X Y Z 9	X/No Upper, Lower Case, Predictive Text & Numerical	5 J K L 5	0 0 _	
1 .,?!1@ "-	6 M N O 6	Move Cursor														
2 A B C 2	7 P Q R S 7	Chime Copy Text to Memory														
3 D E F 3	8 T U V 8	Part Paste Text from Memory														
4 G H I 4	9 W X Y Z 9	X/No Upper, Lower Case, Predictive Text & Numerical														
5 J K L 5	0 0 _															
checkmark/Yes	<b>Auxiliary Input</b> Press X/No to edit, 0 - 7 to select an input type, checkmark/Yes to accept <table border="0" style="width: 100%;"> <tr> <td>0 Not Used</td> <td>6 Silence Sounders</td> </tr> <tr> <td>1 Auxiliary Tamper</td> <td>7 Global Omit Key</td> </tr> <tr> <td>2 Bell Tamper</td> <td>8 Local Omit Key</td> </tr> <tr> <td>3 Remote Reset</td> <td>9 PSU Monitor</td> </tr> <tr> <td>4 Line Fault +ve</td> <td>Defer Auto Arming</td> </tr> <tr> <td>5 Line Fault -ve</td> <td></td> </tr> </table>	0 Not Used	6 Silence Sounders	1 Auxiliary Tamper	7 Global Omit Key	2 Bell Tamper	8 Local Omit Key	3 Remote Reset	9 PSU Monitor	4 Line Fault +ve	Defer Auto Arming	5 Line Fault -ve				
0 Not Used	6 Silence Sounders															
1 Auxiliary Tamper	7 Global Omit Key															
2 Bell Tamper	8 Local Omit Key															
3 Remote Reset	9 PSU Monitor															
4 Line Fault +ve	Defer Auto Arming															
5 Line Fault -ve																
checkmark/Yes	<b>Volume</b> Press X/No to edit, 0 - 8 to enter a value, checkmark/Yes to accept															
checkmark/Yes	<b>Sounder Options</b> Press X/No to edit, arrow to select an option, X/No to change the option, checkmark/Yes to accept <table border="0" style="width: 100%;"> <tr> <td>1 F = Fire Tones Enabled</td> <td>5 E = Entry Tones Enabled</td> </tr> <tr> <td>2 A = Alarm Tones Enabled</td> <td>6 X = Exit Tones Enabled</td> </tr> <tr> <td>3 F = Fault Tones Enabled</td> <td>7 C = Chime Tones Enabled</td> </tr> <tr> <td>4 S = Service Tones Enabled</td> <td></td> </tr> </table>	1 F = Fire Tones Enabled	5 E = Entry Tones Enabled	2 A = Alarm Tones Enabled	6 X = Exit Tones Enabled	3 F = Fault Tones Enabled	7 C = Chime Tones Enabled	4 S = Service Tones Enabled								
1 F = Fire Tones Enabled	5 E = Entry Tones Enabled															
2 A = Alarm Tones Enabled	6 X = Exit Tones Enabled															
3 F = Fault Tones Enabled	7 C = Chime Tones Enabled															
4 S = Service Tones Enabled																

# 6 System Outputs




6	System Outputs	
0 1 2 3	Panel Outputs Digi Outputs Digi Channels RedCARE Pins (Relay pins when using <i>RMB</i> )	Use 1 - 8 to select an output, X/No to edit, 1 - 7 to enter an output group, 0 - 9 to enter output type, ✓/Yes to accept
4 5	Keypad Outputs Expander Outputs	Use 1 - 8 to select device, 0 to select network, ⇅ to select an output, X/No to edit, 1 - 7 to enter an output group, 0 - 9 to enter output type, ✓/Yes to accept
6	Custom Outputs	Use 0 to select output, 1 - 8 to select a switch, X/No to edit, 1 - 7 to enter an output group, 0 - 9 to enter output type, ✓/Yes to accept
7	X-10 Outputs	Use 1 - 8 to select an output, X/No to edit, 1 - 7 to enter an output group, 0 - 9 to enter output type, 0 - 9 to enter House/device Number, ✓/Yes to accept

Key	Output Group	Outputs Types																																													
0	Not Used:	Press ✓/Yes to accept																																													
1	System:	Use 0 - 9 to enter an output type or use ⇅ to search, ✓/Yes to accept																																													
		<table border="0"> <tr> <td>00: ATS Path Fault</td> <td>23: Custom 1 Stage B</td> <td>44: Com Port Fault</td> </tr> <tr> <td>01: Mains Power Off</td> <td>24: Custom 1 Stage A or B</td> <td>45: Radio Jamming</td> </tr> <tr> <td>02: Power Output Fault</td> <td>25: Custom 2 Stage A</td> <td>46: Radio RX Tamper</td> </tr> <tr> <td>03: Bell Tamper</td> <td>26: Custom 2 Stage B</td> <td>47: Detector Test</td> </tr> <tr> <td>04: Auxiliary Tamper</td> <td>27: Custom 2 Stage A or B</td> <td>48: ATS Remote Test</td> </tr> <tr> <td>05: Panel Lid Tamper</td> <td>28: Radio-Pad Failed</td> <td>49: No ATS Available</td> </tr> <tr> <td>06: Engineer Working</td> <td>29: Radio-Pad Successful</td> <td>50: CIE Fault</td> </tr> <tr> <td>07: Confirm Devices</td> <td>30: No Radio Signal</td> <td>51: PSU Fuse Blown</td> </tr> <tr> <td>08: Service Required</td> <td>31: Radio-Pad Lost</td> <td>52: PSU Battery Fault</td> </tr> <tr> <td>09: System Over Voltage</td> <td>30: No Radio-Pad Signal</td> <td>53: WD Test Active</td> </tr> <tr> <td>10: Battery Fault</td> <td>31: Radio-Pad Lost</td> <td>54: PSU Mains Fault</td> </tr> <tr> <td>11: Battery Test On</td> <td>32: Custom 3 Stage A</td> <td>55: Com 1 Power On</td> </tr> <tr> <td>12: Courtesy Light</td> <td>33: Custom 3 Stage B</td> <td>56: Com 2 Power On</td> </tr> <tr> <td>13: System Open</td> <td>34: Custom 3 Stage A or B</td> <td>57: Com 3 Power On</td> </tr> <tr> <td>14: Fully Armed</td> <td>35: Custom 4 Stage A</td> <td>58: IP Path Fault</td> </tr> </table>	00: ATS Path Fault	23: Custom 1 Stage B	44: Com Port Fault	01: Mains Power Off	24: Custom 1 Stage A or B	45: Radio Jamming	02: Power Output Fault	25: Custom 2 Stage A	46: Radio RX Tamper	03: Bell Tamper	26: Custom 2 Stage B	47: Detector Test	04: Auxiliary Tamper	27: Custom 2 Stage A or B	48: ATS Remote Test	05: Panel Lid Tamper	28: Radio-Pad Failed	49: No ATS Available	06: Engineer Working	29: Radio-Pad Successful	50: CIE Fault	07: Confirm Devices	30: No Radio Signal	51: PSU Fuse Blown	08: Service Required	31: Radio-Pad Lost	52: PSU Battery Fault	09: System Over Voltage	30: No Radio-Pad Signal	53: WD Test Active	10: Battery Fault	31: Radio-Pad Lost	54: PSU Mains Fault	11: Battery Test On	32: Custom 3 Stage A	55: Com 1 Power On	12: Courtesy Light	33: Custom 3 Stage B	56: Com 2 Power On	13: System Open	34: Custom 3 Stage A or B	57: Com 3 Power On	14: Fully Armed	35: Custom 4 Stage A	58: IP Path Fault
00: ATS Path Fault	23: Custom 1 Stage B	44: Com Port Fault																																													
01: Mains Power Off	24: Custom 1 Stage A or B	45: Radio Jamming																																													
02: Power Output Fault	25: Custom 2 Stage A	46: Radio RX Tamper																																													
03: Bell Tamper	26: Custom 2 Stage B	47: Detector Test																																													
04: Auxiliary Tamper	27: Custom 2 Stage A or B	48: ATS Remote Test																																													
05: Panel Lid Tamper	28: Radio-Pad Failed	49: No ATS Available																																													
06: Engineer Working	29: Radio-Pad Successful	50: CIE Fault																																													
07: Confirm Devices	30: No Radio Signal	51: PSU Fuse Blown																																													
08: Service Required	31: Radio-Pad Lost	52: PSU Battery Fault																																													
09: System Over Voltage	30: No Radio-Pad Signal	53: WD Test Active																																													
10: Battery Fault	31: Radio-Pad Lost	54: PSU Mains Fault																																													
11: Battery Test On	32: Custom 3 Stage A	55: Com 1 Power On																																													
12: Courtesy Light	33: Custom 3 Stage B	56: Com 2 Power On																																													
13: System Open	34: Custom 3 Stage A or B	57: Com 3 Power On																																													
14: Fully Armed	35: Custom 4 Stage A	58: IP Path Fault																																													

		15: Coms Failed	36: Custom 4 Stage B	59: Low Fob Battery
		16: Coms Successful	37: Custom 4 Stage A or B	60: PS Failure
		17: Coms Active	38: Com 1 Fault	61: Charger Fault
		18: UDL Lockout	39: Com 2 Fault	62: GSM Tamper
		19: UDL Call Active	40: Com 3 Fault	63: Auxiliary Fault
		20: UDL Enabled	41: Com 1 No Signal	64: Poll Timer
		21: Confirmed Alarm	42: Com 2 No Signal	
		22: Custom 1 Stage A	43: Com 3 No Signal	
<b>2</b>	<b>Area:</b>	<b>12/24/48/64/88/168</b>		
		Use <b>0</b> - <b>9</b> to enter an output type or use <b>↔</b> to search, <b>1</b> - <b>8</b> to select an area, <b>0</b> = all areas, <b>Area</b> = areas A - H and I - P), <b>✓/Yes</b> to accept		
		<b>640</b>		
		Use <b>0</b> - <b>9</b> to enter an output type or use <b>↔</b> to search, <b>↔</b> to select an area, <b>✓/Yes</b> to accept type, <b>Chime</b> - <b>Part</b> to select an area group (1-4), use <b>Area</b> to select areas A - H and I - P), <b>✓/Yes</b> to accept.		
		00: Alarm	25: Force Arm	50: Part Armed 1
		01: Guard Alarm	26: Force Armed	51: Part Armed 2
		02: Guard Access Alarm	27: Arm Fail	52: Part Armed 3
		03: Entry Alarm	28: Bell SAB	53: Custom Alarm
		04: Confirmed Intruder	29: Bell SCB	54: Zone Warning
		05: 24Hr Audible	30: Strobe	55: Arm Fail Warning
		06: 24Hr Silent	31: Detector Latch	56: Forced Entry
		07: 24Hr Gas	32: Detector Reset	57: Zones Locked Out
		08: PA Audible	33: Walk Test	58: All Armed
		09: PA Silent	34: Omitted	59: Time Arm Disabled
		10: Duress	35: 24Hr Omit	60: Armed / Alarm
		11: Fire Alarm	36: Reset Required	61: Intruder Alarm
		12: Medical	37: Door Strike	62: Speaker Mimic
		13: Auxiliary Alarm	38: Chime Mimic	63: Full Arm/Exit
		14: Tamper Alarm	39: Chime Enabled	64: Detector Fault
		15: Alarm Abort	40: Double Knock Active	65: Detector Masked
		16: Ready	41: Beam Pair	66: Fault Present
		17: Entry Mode	42: Zone on Test	67: LED Control
		18: 2 <sup>nd</sup> Entry Mode	43: Test Failed	68: Full Armed Entry
		19: Exit Mode	44: Internal Alarm	69: Fire Sounder
		20: Entry/Exit Mode	45: Auto Arming	70: Confirmed PA
		21: Armed	46: Time Arming	71: Confirmed Intruder
		22: Full Arm	47: 1 <sup>st</sup> Code Entered	72: Seismic Alarm*
		23: Part Armed	48: 2 <sup>nd</sup> Code Entered	
		24: Part Arming	49: Area Secured	<i>*for future use</i>
<b>3</b>	<b>Zone:</b>	Use <b>1</b> - <b>8</b> to enter a zone number or use <b>↔</b> to search, <b>0</b> - <b>5</b> to select a zone output type, <b>✓/Yes</b> to accept		
		<b>0</b> Mimic	<b>2</b> Alarm	<b>4</b> MimicLatch
		<b>1</b> MimicArm	<b>3</b> Tamper	<b>5</b> Omitted
<b>4</b>	<b>User:</b>	Use <b>0</b> - <b>8</b> to select a User code or use <b>↔</b> to search, <b>✓/Yes</b> to accept		
<b>5</b>	<b>Control Timer:</b>	Use <b>1</b> - <b>8</b> to select a Control Timer, <b>✓/Yes</b> to accept		
<b>6</b>	<b>PC Control:</b>	Use <b>1</b> - <b>8</b> to select a PC Control, <b>✓/Yes</b> to accept		
<b>7</b>	<b>Door Control:</b>	Use <b>0</b> - <b>9</b> to select a Door Control, <b>✓/Yes</b> to accept		
<b>8</b>	<b>Zone Group</b>	Use <b>0</b> - <b>1</b> to select the output function, <b>✓/Yes</b> to accept <b>1</b> - <b>9</b> to select the Zone Group		

Key	Attributes	Attribute Types								
<b>✓/Yes</b>	Attributes	Press <b>✓/Yes</b> on the output to go to attributes to , Press <b>X/No</b> to edit , use <b>1</b> - <b>8</b> to select attributes, Press <b>✓/Yes</b> to accept								
		<table border="0"> <tr> <td><b>1</b> U = User Test</td> <td><b>5</b> 2 = Use Pulse Timer 2</td> </tr> <tr> <td><b>2</b> I = Inverted</td> <td><b>6</b> 3 = Use Pulse Timer 3</td> </tr> <tr> <td><b>3</b> L = Latching</td> <td><b>7</b> C = Custom Output 1, Stage A</td> </tr> <tr> <td><b>4</b> 1 = Use Pulse Timer 1</td> <td><b>8</b> R = Random</td> </tr> </table>	<b>1</b> U = User Test	<b>5</b> 2 = Use Pulse Timer 2	<b>2</b> I = Inverted	<b>6</b> 3 = Use Pulse Timer 3	<b>3</b> L = Latching	<b>7</b> C = Custom Output 1, Stage A	<b>4</b> 1 = Use Pulse Timer 1	<b>8</b> R = Random
<b>1</b> U = User Test	<b>5</b> 2 = Use Pulse Timer 2									
<b>2</b> I = Inverted	<b>6</b> 3 = Use Pulse Timer 3									
<b>3</b> L = Latching	<b>7</b> C = Custom Output 1, Stage A									
<b>4</b> 1 = Use Pulse Timer 1	<b>8</b> R = Random									

# 7 UDL/Digi Options




7	UDL/Digi Options	
0	<b>Reset Digi</b>	Press <input checked="" type="checkbox"/> /Yes to reset communicator
1	<b>Start Test call</b>	Press 0 to send test call to the ARC, 1 - 3 to initiate a call to the remote UDL computer (using Call Back numbers 1, 2 or 3)
2	<b>Msn Pre Dial Number</b>	Press No to edit, enter call waiting number, <input checked="" type="checkbox"/> /Yes to accept 0 - 9 = Numbers 0 to 9 <span style="float:right"><input type="checkbox"/> Chime Insert a '#'</span> <input checked="" type="checkbox"/> /No then Yes = Clear Screen <span style="float:right"><input type="checkbox"/> Part , (3 Second pause)</span> <input type="checkbox"/> Omit Insert a '*' <span style="float:right"><input type="checkbox"/> Area W (10 Second pause)</span>
3	<b>Program Digi</b>	Use <input type="checkbox"/> to select ARC sets 1 - 5, No to edit
	<b>Protocol Options</b>	Press <input checked="" type="checkbox"/> /No to edit, 0 - 6 to select protocol, <input checked="" type="checkbox"/> /Yes to accept 0 Disabled <span style="margin-left: 100px;">3 SIA Level II</span> <span style="margin-left: 100px;">6 Speech Module</span> 1 Fast Format <span style="margin-left: 100px;">4 EasyCom Pager</span> <span style="margin-left: 100px;">7 Texecom Connect</span> 2 Contact ID <span style="margin-left: 100px;">5 SMS</span>
	<b>Primary Number</b>	Press <input checked="" type="checkbox"/> /No to edit, 0 - 9 to enter telephone number, <input checked="" type="checkbox"/> /Yes to accept
	<b>Secondary Number</b>	Press <input checked="" type="checkbox"/> /No to edit, 0 - 9 to enter number, <input checked="" type="checkbox"/> /Yes to accept
	<b>Account Number</b>	Press <input checked="" type="checkbox"/> /No to edit, 0 - 9 to enter number, <input checked="" type="checkbox"/> /Yes to accept
	<b>Dialling Attempts</b>	Press <input checked="" type="checkbox"/> /No to edit, 0 - 9 to enter number, <input checked="" type="checkbox"/> /Yes to accept
	<b>Reporting Channels</b>	Press <input checked="" type="checkbox"/> /No to edit, 1 - 8 to select channels, <input checked="" type="checkbox"/> /Yes to accept (only available for Fast Format)
	<b>Restoring Channels</b>	Press <input checked="" type="checkbox"/> /No to edit, 1 - 8 to select channels, <input checked="" type="checkbox"/> /Yes to accept (only available for Fast Format)
	<b>Open/Close Channels</b>	Press <input checked="" type="checkbox"/> /No to edit, 1 - 8 to select channels, <input checked="" type="checkbox"/> /Yes to accept (only available for Fast Format)
	<b>Reporting Areas 12/24/48/64/88/168</b>	Press <input checked="" type="checkbox"/> /No to edit, 1 - 8 to select an area, 0 = all areas, <input type="checkbox"/> Area = areas A - H and I -P, <input checked="" type="checkbox"/> /Yes to accept (only available for Contact ID, SIA Level II, EasyCom Pager, SMS Messaging and Speech Module)
<b>Reporting Areas 640</b>	Press <input checked="" type="checkbox"/> /No to edit, <input type="checkbox"/> Chime - <input type="checkbox"/> Part to select an area group (1-4), use <input type="checkbox"/> Area to select areas A - H and I -P, <input checked="" type="checkbox"/> /Yes to accept. (only available for Contact ID, SIA Level II, EasyCom Pager and SMS Messaging)	

7 UDL/Digi Options									
Reporting Options	Press <b>X</b> / <b>No</b> to edit, <b>1</b> - <b>8</b> to select option, <b>✓</b> / <b>Yes</b> to accept (only available for Contact ID, SIA Level II, EasyCom Pager, SMS Messaging and Speech Module)								
	<table border="0"> <tr> <td><b>1</b> P = Priority Alarms</td> <td><b>5</b> M = Maintenance</td> </tr> <tr> <td><b>2</b> A = Normal Alarms</td> <td><b>6</b> T = Tamper Alarms</td> </tr> <tr> <td><b>3</b> C = Open/Close</td> <td><b>7</b> C = Test Calls</td> </tr> <tr> <td><b>4</b> O = Omits &amp; Reinstates</td> <td><b>8</b> R = Restores</td> </tr> </table>	<b>1</b> P = Priority Alarms	<b>5</b> M = Maintenance	<b>2</b> A = Normal Alarms	<b>6</b> T = Tamper Alarms	<b>3</b> C = Open/Close	<b>7</b> C = Test Calls	<b>4</b> O = Omits & Reinstates	<b>8</b> R = Restores
<b>1</b> P = Priority Alarms	<b>5</b> M = Maintenance								
<b>2</b> A = Normal Alarms	<b>6</b> T = Tamper Alarms								
<b>3</b> C = Open/Close	<b>7</b> C = Test Calls								
<b>4</b> O = Omits & Reinstates	<b>8</b> R = Restores								
Config 1:	Press <b>X</b> / <b>No</b> to edit, <b>1</b> - <b>8</b> to select option, <b>✓</b> / <b>Yes</b> to accept								
	<table border="0"> <tr> <td><b>1</b> A = Use Area Acc</td> <td><b>5</b> A = Activate AV</td> </tr> <tr> <td><b>2</b> S = Use SIA I</td> <td><b>6</b> F = Use GSM First</td> </tr> <tr> <td><b>3</b> R = Enable RadioPad</td> <td><b>7</b> I = Connect Via IP</td> </tr> <tr> <td><b>4</b> G = Enable GSM</td> <td><b>8</b> T = Send SIA Text</td> </tr> </table>	<b>1</b> A = Use Area Acc	<b>5</b> A = Activate AV	<b>2</b> S = Use SIA I	<b>6</b> F = Use GSM First	<b>3</b> R = Enable RadioPad	<b>7</b> I = Connect Via IP	<b>4</b> G = Enable GSM	<b>8</b> T = Send SIA Text
<b>1</b> A = Use Area Acc	<b>5</b> A = Activate AV								
<b>2</b> S = Use SIA I	<b>6</b> F = Use GSM First								
<b>3</b> R = Enable RadioPad	<b>7</b> I = Connect Via IP								
<b>4</b> G = Enable GSM	<b>8</b> T = Send SIA Text								
Config 2:	Press <b>X</b> / <b>No</b> to edit, <b>1</b> - <b>3</b> to select option, <b>✓</b> / <b>Yes</b> to accept								
	<table border="0"> <tr> <td><b>1</b> 1 = Use Com Port 1</td> <td><b>3</b> 3 = Use Com Port 3</td> </tr> <tr> <td><b>2</b> 2 = Use Com Port 2</td> <td><b>4</b> 4 = Add Push Message</td> </tr> </table>	<b>1</b> 1 = Use Com Port 1	<b>3</b> 3 = Use Com Port 3	<b>2</b> 2 = Use Com Port 2	<b>4</b> 4 = Add Push Message				
<b>1</b> 1 = Use Com Port 1	<b>3</b> 3 = Use Com Port 3								
<b>2</b> 2 = Use Com Port 2	<b>4</b> 4 = Add Push Message								
4 Digi Options	Press <b>X</b> / <b>No</b> to edit, <b>↕</b> to select an option, <b>X</b> / <b>No</b> to change the option, <b>✓</b> / <b>Yes</b> to accept								
	<table border="0"> <tr> <td><b>1</b> E = Digi is Enabled</td> <td><b>4</b> B = Blind Dialling</td> </tr> <tr> <td><b>2</b> P = Pulse Dialling</td> <td><b>5</b> W = Call Waiting On</td> </tr> <tr> <td><b>3</b> 3 = Pulse after 3</td> <td><b>6</b> A = Dial All Numbers</td> </tr> </table>	<b>1</b> E = Digi is Enabled	<b>4</b> B = Blind Dialling	<b>2</b> P = Pulse Dialling	<b>5</b> W = Call Waiting On	<b>3</b> 3 = Pulse after 3	<b>6</b> A = Dial All Numbers		
<b>1</b> E = Digi is Enabled	<b>4</b> B = Blind Dialling								
<b>2</b> P = Pulse Dialling	<b>5</b> W = Call Waiting On								
<b>3</b> 3 = Pulse after 3	<b>6</b> A = Dial All Numbers								
4* Enable Texecom Connect App	<p><b>THIS MENU ONLY APPEARS ONCE THE TEXECOM CONNECT PROTOCOL HAS BEEN SELECTED. SUBSEQUENT MENUS ARE INCREMENTED ACCORDINGLY SO 5 BECOMES 6 etc</b></p> <p>Used to enable the Connect App. Communicates with our secure servers and issues an app code to be entered into the Users Smart device.</p>								
5 UDL Options	Press <b>X</b> / <b>No</b> to edit Call Back number 1, enter the number, <b>✓</b> / <b>Yes</b> to accept								
	<table border="0"> <tr> <td><b>0</b> - <b>9</b> = Numbers 0 to 9</td> <td><b>🎵</b> /Chime Insert a '#'</td> </tr> <tr> <td><b>X</b>/<b>No</b> then <b>Yes</b> = Clear Screen</td> <td><b>🏠</b> /Part , (3 Second pause)</td> </tr> <tr> <td><b>Omit</b> Insert a '*'</td> <td><b>🏠</b> /Area W (10 Second pause)</td> </tr> </table>	<b>0</b> - <b>9</b> = Numbers 0 to 9	<b>🎵</b> /Chime Insert a '#'	<b>X</b> / <b>No</b> then <b>Yes</b> = Clear Screen	<b>🏠</b> /Part , (3 Second pause)	<b>Omit</b> Insert a '*'	<b>🏠</b> /Area W (10 Second pause)		
<b>0</b> - <b>9</b> = Numbers 0 to 9	<b>🎵</b> /Chime Insert a '#'								
<b>X</b> / <b>No</b> then <b>Yes</b> = Clear Screen	<b>🏠</b> /Part , (3 Second pause)								
<b>Omit</b> Insert a '*'	<b>🏠</b> /Area W (10 Second pause)								
Call Back Number 2	Press <b>X</b> / <b>No</b> to edit Call Back number 2, enter the number, <b>Yes</b> to accept								
Call Back Number 3	Press <b>X</b> / <b>No</b> to edit Call Back number 3, enter the number, <b>Yes</b> to accept								
UDL Password	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter number, <b>Yes</b> to accept								
UDL options	Press <b>X</b> / <b>No</b> to edit, <b>↕</b> to select an option, <b>X</b> / <b>No</b> to change option, <b>Yes</b> to accept								
	<table border="0"> <tr> <td><b>1</b> A = Attended Download</td> <td><b>4</b> L = Restrict Download when Armed</td> </tr> <tr> <td><b>2</b> M = Manual Call-back</td> <td><b>5</b> A = Download when Part Armed</td> </tr> <tr> <td><b>3</b> D = 2-Call Answer Phone Defeat</td> <td><b>6</b> K = Online RKP = Off)</td> </tr> </table>	<b>1</b> A = Attended Download	<b>4</b> L = Restrict Download when Armed	<b>2</b> M = Manual Call-back	<b>5</b> A = Download when Part Armed	<b>3</b> D = 2-Call Answer Phone Defeat	<b>6</b> K = Online RKP = Off)		
<b>1</b> A = Attended Download	<b>4</b> L = Restrict Download when Armed								
<b>2</b> M = Manual Call-back	<b>5</b> A = Download when Part Armed								
<b>3</b> D = 2-Call Answer Phone Defeat	<b>6</b> K = Online RKP = Off)								
Rings Required	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter number of rings, <b>✓</b> / <b>Yes</b> to accept								
UDL Dial Attempt	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter number of dialling attempts, <b>✓</b> / <b>Yes</b> to accept								
6 Area Accounts	Use <b>↕</b> to select an area, <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter account number, <b>✓</b> / <b>Yes</b> to accept								
7 Setup Modules	Press <b>🔄</b> /Reset to reset communicator								
Setup Radio-Pad?	Press <b>✓</b> / <b>Yes</b> to set-up Radio-Pad, <b>☰</b> /Menu to exit								
Pad ARC 1 Pri No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 1 Sec No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 1 Prefix	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter pad prefix, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 2 Pri No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 2 Sec No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 2 Prefix	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter pad prefix, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 3 Pri No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 3 Sec No	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
Pad ARC 3 Prefix	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter pad prefix, <b>✓</b> / <b>Yes</b> to accept								
Setup AV Module?	Press <b>✓</b> / <b>Yes</b> to set-up AV Module, <b>☰</b> /Menu to exit								
AV No.1	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
AV No.2	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
AV No.3	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter telephone number, <b>✓</b> / <b>Yes</b> to accept								
AV Dial Attempts	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter number of dialling attempts, <b>✓</b> / <b>Yes</b> to accept								
AV Re-Dial Delay	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter the re-dial delay, <b>✓</b> / <b>Yes</b> to accept								
Setup IP Data?	Press <b>✓</b> / <b>Yes</b> to set-up IP Module, <b>☰</b> /Menu to exit								
Select Com Port?	Use <b>↕</b> to select Com Port 1,2 or 3, <b>✓</b> / <b>Yes</b> to continue <b>☰</b> /Menu to exit								
ComIP Address	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter an IP Address, <b>✓</b> / <b>Yes</b> to accept								
ComIP Port	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter a Port Number, <b>✓</b> / <b>Yes</b> to accept								
ComIP Gateway	Press <b>X</b> / <b>No</b> to edit, <b>0</b> - <b>9</b> to enter a Gateway Address, <b>✓</b> / <b>Yes</b> to accept								




7 UDL/Digi Options													
ComIP Mask	Press (X/No) to edit, (0-9) to enter a Subnet Mask, (✓/Yes) to accept												
Polling /SMG IP	Press (X/No) to edit, (0-9) to an IP Address, (✓/Yes) to accept												
Name/SMG Port	Press (X/No) to edit, (0-9) to a Name, (✓/Yes) to accept												
Setup GPRS Data?	Press (✓/Yes) to set-up Chiron IRIS GPRS Data, (Menu) to exit												
Access Pnt Name	Press (X/No) to edit, (0-9) to enter an Access Point Name, (✓/Yes) to accept												
User Name	Press (X/No) to edit, (0-9) to enter a User Name, (✓/Yes) to accept												
Password	Press (X/No) to edit, (0-9) to enter a Password, (✓/Yes) to accept												
SMS Centre Pri	Press (X/No) to edit, (0-9) to enter telephone number, (✓/Yes) to accept												
SMS Centre Sec	Press (X/No) to edit, (0-9) to enter telephone number, (✓/Yes) to accept												
Modem Setup Stg.	Press (X/No) to edit, (0-9) to enter modem string, (✓/Yes) to accept												
Modem Speed	Press (X/No) to edit, (0-9) to enter telephone number, (✓/Yes) to accept												
Pad ESN	View only												
Pad NUA	View only												
Forward Signal	View only												
Reverse Signal	View only												
Bit Error Rate	View only												
Cyclic Redundancy	View only												
GSM Signal/BER	View only												
Com1,2,3	Press (Reset) to reset com port												
8 Com Port Setup													
	Use (0-3) to select a com port, (X/No) to edit, (↕) to select an option, (✓/Yes) to accept												
Onboard Digi Port	<table border="0"> <tr> <td>(0) Nothing Fitted</td> <td>(6) Radio-pad</td> <td>(↕) WebWayOne/Emizon Module</td> </tr> <tr> <td>(1) Com300</td> <td>(7) GSM Module</td> <td>(↕) X-10 Control</td> </tr> </table>	(0) Nothing Fitted	(6) Radio-pad	(↕) WebWayOne/Emizon Module	(1) Com300	(7) GSM Module	(↕) X-10 Control						
(0) Nothing Fitted	(6) Radio-pad	(↕) WebWayOne/Emizon Module											
(1) Com300	(7) GSM Module	(↕) X-10 Control											
Com Ports 1, 2 & 3	<table border="0"> <tr> <td>(2) Com2400</td> <td>(8) Crestron System</td> <td>(↕) IRIS IP Module</td> </tr> <tr> <td>(3) ComISDN</td> <td>(9) SIP</td> <td>(↕) SmartCom</td> </tr> <tr> <td>(4) ComIP</td> <td>(↕) RadioPlus</td> <td></td> </tr> <tr> <td>(5) Modem Unit</td> <td>(↕) Inovonics Radio</td> <td></td> </tr> </table>	(2) Com2400	(8) Crestron System	(↕) IRIS IP Module	(3) ComISDN	(9) SIP	(↕) SmartCom	(4) ComIP	(↕) RadioPlus		(5) Modem Unit	(↕) Inovonics Radio	
(2) Com2400	(8) Crestron System	(↕) IRIS IP Module											
(3) ComISDN	(9) SIP	(↕) SmartCom											
(4) ComIP	(↕) RadioPlus												
(5) Modem Unit	(↕) Inovonics Radio												
Expansion Port	<table border="0"> <tr> <td>(0) Nothing Fitted</td> <td>(2) ID Module</td> <td>(4) Memory Module</td> </tr> <tr> <td>(1) AV Module</td> <td>(3) X10 Module</td> <td>(5) Speech Module</td> </tr> </table>	(0) Nothing Fitted	(2) ID Module	(4) Memory Module	(1) AV Module	(3) X10 Module	(5) Speech Module						
(0) Nothing Fitted	(2) ID Module	(4) Memory Module											
(1) AV Module	(3) X10 Module	(5) Speech Module											

## 8 Setup Users



8 Setup Users																
✓/Yes	<p><b>Select User</b></p> <p>Use <b>0</b> - <b>9</b> to enter enter a user number, <b>Reset</b> to Delete User, <b>Omit</b> to assign a Radio FOB, <b>Chime</b> to Copy a TAG, <b>Part</b> to Import a TAG, <b>Yes</b> to enter a Code</p>															
✓/Yes	<p><b>User Code</b></p> <p>Use <b>0</b> - <b>9</b> to enter a code, <b>✓/Yes</b> to accept</p>															
✓/Yes	<p><b>User Areas</b> 12/24/48/64/88/168</p> <p>Use <b>1</b> - <b>8</b> to select an area, <b>0</b> = all areas, <b>Area</b> = areas A - H and I -P), <b>✓/Yes</b> to accept</p>															
✓/Yes	<p><b>User Areas 640</b></p> <p>Use <b>Chime</b> - <b>Part</b> to select an area group (1-4), use <b>Area</b> to select areas A - H and I -P, <b>✓/Yes</b></p>															
✓/Yes	<p><b>User Types</b></p> <p>Use <b>0</b> - <b>9</b> to select a user type, <b>Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> Master</td> <td style="width: 33%;"><b>5</b> Arm Only</td> <td style="width: 33%;"><b>9</b> Custom</td> </tr> <tr> <td><b>2</b> Manager</td> <td><b>6</b> Duress</td> <td><b>0</b> Engineer</td> </tr> <tr> <td><b>3</b> Standard</td> <td><b>7</b> Door Strike</td> <td><b>↕</b> Prevent Unset</td> </tr> <tr> <td><b>4</b> Local</td> <td><b>8</b> Vacation</td> <td></td> </tr> </table>	<b>1</b> Master	<b>5</b> Arm Only	<b>9</b> Custom	<b>2</b> Manager	<b>6</b> Duress	<b>0</b> Engineer	<b>3</b> Standard	<b>7</b> Door Strike	<b>↕</b> Prevent Unset	<b>4</b> Local	<b>8</b> Vacation				
<b>1</b> Master	<b>5</b> Arm Only	<b>9</b> Custom														
<b>2</b> Manager	<b>6</b> Duress	<b>0</b> Engineer														
<b>3</b> Standard	<b>7</b> Door Strike	<b>↕</b> Prevent Unset														
<b>4</b> Local	<b>8</b> Vacation															
✓/Yes	<p><b>User Options 1</b></p> <p>Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change option, <b>✓/Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> A = Arming</td> <td style="width: 33%;"><b>4</b> R = Eng. Reset</td> <td style="width: 33%;"><b>7</b> Y = Auto 'YES'</td> </tr> <tr> <td><b>2</b> D = Disarming</td> <td><b>5</b> a = Local Arming</td> <td><b>8</b> D = Disarm First</td> </tr> <tr> <td><b>3</b> O = Omitting</td> <td><b>6</b> d = Local Disarming</td> <td></td> </tr> </table>	<b>1</b> A = Arming	<b>4</b> R = Eng. Reset	<b>7</b> Y = Auto 'YES'	<b>2</b> D = Disarming	<b>5</b> a = Local Arming	<b>8</b> D = Disarm First	<b>3</b> O = Omitting	<b>6</b> d = Local Disarming							
<b>1</b> A = Arming	<b>4</b> R = Eng. Reset	<b>7</b> Y = Auto 'YES'														
<b>2</b> D = Disarming	<b>5</b> a = Local Arming	<b>8</b> D = Disarm First														
<b>3</b> O = Omitting	<b>6</b> d = Local Disarming															
✓/Yes	<p><b>User Options 2</b> (only available to Custom users)</p> <p>Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change option, <b>✓/Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> U = User Menu</td> <td style="width: 33%;"><b>4</b> V = Vacation</td> <td style="width: 33%;"><b>7</b> C = Duress Code</td> </tr> <tr> <td><b>2</b> E = Eng. Program</td> <td><b>5</b> S = Door strike</td> <td><b>8</b> O = Open/Close</td> </tr> <tr> <td><b>3</b> D = Dual Code</td> <td><b>6</b> R = Call Rem. PC</td> <td></td> </tr> </table>	<b>1</b> U = User Menu	<b>4</b> V = Vacation	<b>7</b> C = Duress Code	<b>2</b> E = Eng. Program	<b>5</b> S = Door strike	<b>8</b> O = Open/Close	<b>3</b> D = Dual Code	<b>6</b> R = Call Rem. PC							
<b>1</b> U = User Menu	<b>4</b> V = Vacation	<b>7</b> C = Duress Code														
<b>2</b> E = Eng. Program	<b>5</b> S = Door strike	<b>8</b> O = Open/Close														
<b>3</b> D = Dual Code	<b>6</b> R = Call Rem. PC															
✓/Yes	<p><b>User Config.</b> (only available to Custom users with User Menu)</p> <p>Press <b>X/No</b> to edit, <b>↕</b> to select an option, <b>X/No</b> to change option, <b>✓/Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> C = Change Code</td> <td style="width: 33%;"><b>4</b> S = System tests</td> <td style="width: 33%;"><b>7</b> A = Add Eng. Code</td> </tr> <tr> <td><b>2</b> Z = Chime Zones</td> <td><b>5</b> U = Setup Users</td> <td><b>8</b> N = NVM Locking</td> </tr> <tr> <td><b>3</b> T = Change Timer</td> <td><b>6</b> E = Eng. Access</td> <td></td> </tr> </table>	<b>1</b> C = Change Code	<b>4</b> S = System tests	<b>7</b> A = Add Eng. Code	<b>2</b> Z = Chime Zones	<b>5</b> U = Setup Users	<b>8</b> N = NVM Locking	<b>3</b> T = Change Timer	<b>6</b> E = Eng. Access							
<b>1</b> C = Change Code	<b>4</b> S = System tests	<b>7</b> A = Add Eng. Code														
<b>2</b> Z = Chime Zones	<b>5</b> U = Setup Users	<b>8</b> N = NVM Locking														
<b>3</b> T = Change Timer	<b>6</b> E = Eng. Access															
✓/Yes	<p><b>User Time Lock</b></p> <p>Use <b>1</b> - <b>8</b> to select a control timer, <b>✓/Yes</b> to accept</p>															
✓/Yes	<p><b>User Text</b></p> <p>Press <b>X/No</b> to edit, <b>0</b> - <b>9</b> to select characters (predictive text is on by default, this may be altered as described below), <b>✓/Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> .,?!1@ "-</td> <td style="width: 33%;"><b>6</b> M N O 6</td> <td style="width: 33%;"><b>↕</b> Move Cursor</td> </tr> <tr> <td><b>2</b> A B C 2</td> <td><b>7</b> P Q R S 7</td> <td><b>Chime</b> Copy Text to Memory</td> </tr> <tr> <td><b>3</b> D E F 3</td> <td><b>8</b> T U V 8</td> <td><b>Part</b> Paste Text from Memory</td> </tr> <tr> <td><b>4</b> G H I 4</td> <td><b>9</b> W X Y Z 9</td> <td><b>Area</b> Upper, Lower Case, Predictive Text &amp; Numerical</td> </tr> <tr> <td><b>5</b> J K L 5</td> <td><b>0</b> 0 _</td> <td></td> </tr> </table>	<b>1</b> .,?!1@ "-	<b>6</b> M N O 6	<b>↕</b> Move Cursor	<b>2</b> A B C 2	<b>7</b> P Q R S 7	<b>Chime</b> Copy Text to Memory	<b>3</b> D E F 3	<b>8</b> T U V 8	<b>Part</b> Paste Text from Memory	<b>4</b> G H I 4	<b>9</b> W X Y Z 9	<b>Area</b> Upper, Lower Case, Predictive Text & Numerical	<b>5</b> J K L 5	<b>0</b> 0 _	
<b>1</b> .,?!1@ "-	<b>6</b> M N O 6	<b>↕</b> Move Cursor														
<b>2</b> A B C 2	<b>7</b> P Q R S 7	<b>Chime</b> Copy Text to Memory														
<b>3</b> D E F 3	<b>8</b> T U V 8	<b>Part</b> Paste Text from Memory														
<b>4</b> G H I 4	<b>9</b> W X Y Z 9	<b>Area</b> Upper, Lower Case, Predictive Text & Numerical														
<b>5</b> J K L 5	<b>0</b> 0 _															
✓/Yes	<p><b>Door Control</b> (only available to Users with Door Strike attribute)</p> <p>Use <b>1</b> - <b>8</b> to select a door, <b>0</b> to select network <b>✓/Yes</b> to accept</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%;"><b>1</b> Door 1</td> <td style="width: 33%;"><b>4</b> Door 4</td> <td style="width: 33%;"><b>7</b> Door 7</td> </tr> <tr> <td><b>2</b> Door 2</td> <td><b>5</b> Door 5</td> <td><b>8</b> Door 8</td> </tr> <tr> <td><b>3</b> Door 3</td> <td><b>6</b> Door 6</td> <td><b>0</b> Select Network</td> </tr> </table>	<b>1</b> Door 1	<b>4</b> Door 4	<b>7</b> Door 7	<b>2</b> Door 2	<b>5</b> Door 5	<b>8</b> Door 8	<b>3</b> Door 3	<b>6</b> Door 6	<b>0</b> Select Network						
<b>1</b> Door 1	<b>4</b> Door 4	<b>7</b> Door 7														
<b>2</b> Door 2	<b>5</b> Door 5	<b>8</b> Door 8														
<b>3</b> Door 3	<b>6</b> Door 6	<b>0</b> Select Network														
✓/Yes	<p><b>Assign Prox TAG</b></p> <p>Press <b>✓/Yes</b> to assign TAG, present TAG to 'Prox' symbol on keypad</p>															

# 9 Engineer Utilities



9		Engineer Utils																			
0	View System Log	Use <input checked="" type="checkbox"/> /Yes to view System, Alarm or Mandatory log																			
	1 System log	Use <input type="up"/> to move up and down through log (down moves back in time, up moves forward again), <input type="home"/> /Area to show area information or time and date, 1 - 7 or <input type="music"/> /Chime to find specific events																			
	2 Alarm Log																				
	3 Mandatory Log																				
	<table border="0"> <tr> <td><input type="up"/></td> <td>Move backwards and forwards</td> <td>4</td> <td>View Omits/Reinstate Events</td> </tr> <tr> <td><input type="home"/>/Area</td> <td>View Area/Time and date</td> <td>5</td> <td>View Maintenance Events</td> </tr> <tr> <td>1</td> <td>View Priority Alarms</td> <td>6</td> <td>View Tamper Alarms</td> </tr> <tr> <td>2</td> <td>View Normal Alarms</td> <td>7</td> <td>View Test Call Events</td> </tr> <tr> <td>3</td> <td>View Open/Close Events</td> <td><input type="music"/>/Chime</td> <td>View Matching Events</td> </tr> </table>	<input type="up"/>	Move backwards and forwards	4	View Omits/Reinstate Events	<input type="home"/> /Area	View Area/Time and date	5	View Maintenance Events	1	View Priority Alarms	6	View Tamper Alarms	2	View Normal Alarms	7	View Test Call Events	3	View Open/Close Events	<input type="music"/> /Chime	View Matching Events
<input type="up"/>	Move backwards and forwards	4	View Omits/Reinstate Events																		
<input type="home"/> /Area	View Area/Time and date	5	View Maintenance Events																		
1	View Priority Alarms	6	View Tamper Alarms																		
2	View Normal Alarms	7	View Test Call Events																		
3	View Open/Close Events	<input type="music"/> /Chime	View Matching Events																		
1	Do Bell Test	Use <input type="up"/> to select an option, use 0 - 8 or <input checked="" type="checkbox"/> /Yes to activate outputs																			
		0 Test Bell	5 Test DIGI Outputs																		
		1 Test Strobe	6 Test Panel Outputs																		
		2 Test Speaker	7 Test RedCare																		
		3 Test User Outputs	8 Test Com300/2400 Channels 1-8																		
		4 LCD Display	9 Test Com300/.2400 Channels 9-16																		
2	Do Walk Test	Press <input type="home"/> /Area to display zones that have been tested/still need testing, <input type="music"/> /Chime to make zones Chime every time they are activated.																			
3	View Zone Status	Use 0 - 9 to enter zone number or use <input type="up"/> to search, <input type="music"/> /Chime to walk test selected zone, Omit to omit zone temporarily																			
4	System Tests	Use 1 - 4 to select an option or use <input type="up"/> to search, Yes to accept																			
		1 View Sys. Status	4 View Version No.																		
		2 View Batt Status	5 View Key Strokes																		
		3 Test Outputs (see Do Bell Test)																			
5	Confirm Devices	Use <input type="up"/> to select network, Yes to confirm Devices, <input type="home"/> /Area to view error count, Reset to reset error count																			
6	Check RKP Status	Use 1 - 8 to select keypad, 0 to select network, <input type="home"/> /Area to display errors/tamper, X/No to test output, <input type="home"/> /Area to test sounder,																			
7	Check Exp. Status	Use 1 - 8 to select expander, 0 to select network, <input type="home"/> /Area to display zones/voltage/outputs/errors, <input type="music"/> /Chime to test zones, <input type="home"/> /Omit to test sounder, 1 - 8 to test outputs																			
8	Set System Time	Use 0 - 9 to enter time (24-hour format) H H M M, <input checked="" type="checkbox"/> /Yes to accept																			
9	Set System Date	Use 0 - 9 to enter date D D M M Y Y, <input checked="" type="checkbox"/> /Yes to accept																			
<input type="up"/>	Location Text	Press Yes to view Location Text																			
<input type="up"/>	Print Log	Use 1 - 8 to enter number of events to be printed, <input checked="" type="checkbox"/> /Yes to print log																			
<input type="up"/>	Start Soak Test	Use 1 - 8 to select an area, (0 = all areas, <input type="home"/> /Area = areas A - H and I -P), <input checked="" type="checkbox"/> /Yes to accept, <input checked="" type="checkbox"/> /Yes to start test																			
<input type="up"/>	Change Eng.Code	Use 0 - 9 to enter a code, <input checked="" type="checkbox"/> /Yes to accept																			
<input type="up"/>	Adjust Volumes	Use <input type="up"/> to select Panel, Keypad or Expander speakers. Press No to edit, 0 - 8 to enter a value, <input checked="" type="checkbox"/> /Yes to accept																			
<input type="up"/>	Default NVM Data	Press 0 - 9 to select an option or <input type="up"/> to search, <input checked="" type="checkbox"/> /Yes to default																			
		0 Panel Outputs	<input type="up"/> Keypad Options																		
		1 Digi Outputs	<input type="up"/> User Codes																		
		2 Com300/2400 Outputs	<input type="up"/> System Timers																		
		3 RedCARE Pins	<input type="up"/> System Options																		
		4 Keypad Outputs	<input type="up"/> Area Options																		
		5 Expander Outputs	<input type="up"/> System Text																		
		6 Custom Outputs	<input type="up"/> UDL Options																		
		7 Zone Types	<input type="up"/> Digi Options																		
		8 Zone Text	<input type="up"/> Reporting Codes																		
9 Expander Options	<input type="up"/> Recipe Data																				
<input type="up"/>	View iD Data	Use 0 to select loop, <input type="home"/> /Area to select normal scan, quick scan or biscuit mapping. Use <input type="up"/> to select biscuit, X/No to edit, 0 - 9 to enter zone number, <input checked="" type="checkbox"/> /Yes to accept																			
<input type="up"/>	Configure Radio	Use 1 - 8 to select a device, <input checked="" type="checkbox"/> /Yes to learn device, X/No to map zone, 1 - 8 to enter zone number, <input checked="" type="checkbox"/> /Yes accept																			
<input type="up"/>	Ricochet Diagnostics	Use 0 - 9 to select a Zone, <input type="music"/> /Chime to scroll through Routing, RSSI, Device Messages, Signal Security & Device Status. <input type="home"/> /Omit switch between Zone Devices & User SmartKeys, <input type="refresh"/> /Reset to default the expander and delete all devices. <input type="home"/> /Part to enter view expanders & networks, whilst viewing expanders press <input checked="" type="checkbox"/> /Yes to view simplified Signal Security.																			
<input type="up"/>	Signalling Test	Use 1 - 8 to toggle areas on or off. <input checked="" type="checkbox"/> /Yes accept areas. Use 1 - 8 to select zones X/No to arm the system as an engineer and carry out the test.																			
<input type="up"/>	View Unique ID	Allows you to view the Unique ID. This ID code is used by our web based applications and Connect app to identify the system and site.																			

# Ricochet Learn

/  *	<b>Ricochet® Learn</b>
Will go to the next available wireless zone starting at 9 or Press  to search. Learning always starts from the next available zone, deleting ways starts from the highest zone learnt to the system. Use the  /  key to start the learn process for the device	
/  Enters the Delete Menu	/  To learn devices

\*Where available.


## Learning & Deleting Ricochet Devices

### Introduction

#### Learn Devices from first power up

When the "Confirm Devices" menu appears check and make sure all installed Keypads and Expanders are showing; press / and / again to confirm.

Providing the system has a Ricochet enabled expander installed, the following will appear. The flow diagram shows the procedure to learn devices:-



### IMPORTANT

In all cases when entering the Learn menu the next available free Zone will be chosen to learn a device too. It will not be possible to learn a device to a Zone that already has a device learned too. The number of expander's on the system will dictate which next "free" zone is chosen to learn too.

When all device slots have been used the following screen will be shown



Pressing the / key will return you to the Ricochet

learn menu; pressing the / key will enter the Delete devices menu.

### Commissioning

#### IMPORTANT

Once all devices are learnt they should be installed in their locations starting closest to the expander and working to furthest away. To start commission mode the receiver should be in Tamper, or in the case of the -W panels place the jumper on "Fit for Commission" position.

Wait for at least 15 minutes and the test all devices.

Device Type	Learn method
Premier Compact All models	Pull battery tab or Insert battery
Impaq Contact & Plus	Short learn pins and insert battery
Odyssey & OdysseyX-W	Insert batteries and move Battery Jumper to ON position
CO-W, OH-W & PA-W	Pull battery tab or Insert battery
Premier Elite QD/XT & DT	Hold down learn switch & insert battery.
SmartKey	Power on
Micro Contact	Hold down button

### Auto Zone Type & Area

When learning devices, if no editing has taken place of the control panel onboard hardwired zones, these will be switched to Not Used after the first Ricochet device is learned to the system; the following defaults will be used for Ricochet devices learned to the system.


Zone	Type	Area
001-008	Not Used	N/A
009	Entry/Exit 1	A
010	Guard Access	A
011 & above	Guard	A

### IMPORTANT

If any editing of any of the on board control panel zones is carried out BEFORE any Ricochet devices are learned too the system, the control panel zones will remain at factory defaults.

#### Access the Learn Menu using the Omit "Hot" key

From any top level engineering menu pressing the / key will take you to the Ricochet learn menu above.




### Deleting Devices

#### Delete Devices

To delete devices from the system, access the Ricochet Learn menu. Any of the methods previously detailed may be used.

The / key is used to access the Delete option.

Follow the flow diagram below to delete devices from the system.



All Devices Deleted!

Pressing the / will return you to the Ricochet learn menu; pressing the / will enter the Learn devices menu.

**Summary of Keys used**

Key	Function
/	Use this key to access the Ricochet Learn menu from any top level engineering menu.
/	Use this key when in Ricochet Learn menu to delete devices, or cycle between learn and delete functions
	Use this key to exit the Learn Menu.

If all devices are deleted from the system the following will be shown

**Premier Elite SmartKey™**

**Introduction**

Premier Elite SmartKey™ are learnt and all functionality managed through the "Setup Users" Menu.

In multiple expander systems it is now possible to choose which zones (and therefore expander) the Premier Elite SmartKey™ will use for its routing, LED and Aux functions can also be changed within the "Setup Users" menu.

Any user on the system can have a Premier Elite SmartKey™ a TAG and a code, or any combination of them.

*NOTE* Each wireless expander can support a maximum of 16 SmartKey™.

All other user programmable options can be found in INS176 Premier Elite Series Installation Manual on the enclosed CD or our website

*NOTE* Great care should be taken when using large numbers of Premier Elite SmartKey™, only one Premier Elite SmartKey™ per expander can be used by the system at any one time, and on Multiple expanders systems, or large sites, functionality should be checked in all areas of the site where the device may be used.

**Premier Elite SmartKey™ Routing**

Premier Elite SmartKey™ should only be learned to the system AFTER all devices have been learned and placed in their final location. Whilst it is possible to learn at any point during the programming of the system, learning and testing the functionality of the Premier Elite SmartKey™ after all devices have been placed will ensure that the Premier Elite SmartKey™ performs as expected, and works in locations where the user would expect it too.

**Route By**

The Route By function allows you to select which Zones (and therefore expander) the Premier Elite SmartKey™ will use on the system for its routing. This should be selected BEFORE the device has been learned.

In the examples below Fig 1 shows the zones associated with Expander 1, which is a 32XP-W, and Fig 2 shows Expander 2 which is also a 32XP-W, when using 8XP-W there will obviously be less devices that the Premier Elite SmartKey™ can use.




Fig 2 The / key is used to select this menu and the key used to select which expander and associated zones will be used

Once a Premier Elite SmartKey™ has been learned the / key will show which zones are being used for routing. It is not possible to alter this once learned. To change the routing the Premier Elite SmartKey™ should be deleted and the process started from the beginning.


**LED & Aux Functions**

Please refer to INS467 Premier 8XP-W/32-W Installation Manual for details of the LED & Aux functions.

**Deleting a Premier Elite SmartKey™**

Deleting the Premier Elite SmartKey™ from the user is a similar process to learning, at the appropriate point in the menu press / followed by / , the Premier Elite SmartKey™ will be removed from the User. To delete all user data see INS176.

**Learning Premier Elite SmartKey™**




\* Please refer to INS467 "Premier Elite SmartKey" for further details on the LED & Aux functions.

**NOTE** Once the 16 slots on a XP-W are taken up, the learn process will fail and display 'No spaces left'.

**NOTE** In either of the Premier Elite SmartKey™ menu displays, any Premier Elite SmartKey™ that logs onto the system will cause the menu to change to that Premier Elite SmartKey™ - a handy

way of finding out which user a Premier Elite SmartKey™ in your hand belongs to!

## ↔ Alter Part Arms



[Home]/Part	Alter Part Arms		
	Press <b>0</b> - <b>9</b> to enter zone number or use [Up/Down] to search, [Home]/Omit, [Chime]/Chime or [Home]/Part to select Part Arms 1, 2 or 3		
[Home]/Omit	Part Arm 1	[Chime]/Chime	Part Arm 2
[Home]/Part	Part Arm 3		

### Notes:

# **Texecom**

Texecom Limited, Bradwood Court, St. Crispin Way, Haslingden, Lancashire BB4 4PW,  
England.

## **Technical Support:**

UK Customers Tel: 08456 300 600

(Calls charged at local rate from a BT landline. Calls from other networks may vary.)

International Customers Tel: +44 1706 233875

Email: [techsupport@texe.com](mailto:techsupport@texe.com)

© Texecom Limited 2017

INS222-10

