

CERTIFICATION of Conformity

No.: MTS/NKC/S16070765

Applicant: **EAST Group Co., Ltd.**
**No.6 Northern Industry Road, Songshan Lake SCI. & TECH.
industrial park, Dongguan City, Guangdong Province, China**

Equipment Description: **UPS**

Model Name: **1000VA, 1200VA, 1500VA, 1600VA, 1750VA, 2000VA, 2200VA,
3000VA**

Trademark: **EAST**

Technical Data: **See annex 1**

This certification refers to the conformity of the following Directives. It does not exclude the product(s) having to be in compliance with other applicable Directives:

According to LVD directive 2014/35/EU

It is to certify that the product identified below is in compliance with the essential requirements of the following standards:

EN 62040-1:2008+A1: 2013

August 16, 2016

Date of Issue



Signed by: Yvette Zhou



This certification of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the Holder's disposal. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

The original document contains watermark. Not to be reproduced without the permission of Most Technology Service Co., Limited.



Most Technology Service Co., Limited

No. 5, 2nd Langshan Road, North District, Hi-tech Industrial Park,
Nanshan, Shenzhen, Guangdong, China

Tel: 86 755 86026850

Fax: 86 755 2601 3350

Http://www.szmost.com

Annex 1

Model	Input	Output	Battery
1000VA	220-240Vac, 1Φ+N+PE, 50/60Hz,6.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 3.0A, 1000VA/600W	12*2=24Vdc, 7.0AH*2 Battery box install inside UPS
1050VA	220-240Vac, 1Φ+N+PE, 50/60Hz,6.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 3.1A, 1050VA/630W	12*2=24Vdc, 7.0AH*2 Battery box install inside UPS
1200VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 6.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 3.3A, 1200VA/720W	12*2=24Vdc, 7.0AH*2 Battery box install inside UPS
1500VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 8.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 4.2A, 1500VA/900W	12*2=24Vdc, 8.0AH*2 Battery box install inside UPS
1600VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 8.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 4.4A, 1600VA/960W	12*2=24Vdc, 8.0AH*2 Battery box install inside UPS
1750VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 8.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 4.8A, 1750VA/1050W	12*2=24Vdc, 8.0AH*2 Battery box install inside UPS
2000VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 10.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 5.5A, 1200VA/1200W	12*2=24Vdc, 9.0AH*2 Battery box install inside UPS
2200VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 10.0A	220-240Vac, 1Φ+N+PE, 50/60Hz, 5.5A, 2200VA/1200W	12*2=24Vdc, 9.0AH*2 Battery box install inside UPS
2500VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 10.0A	Output: 220-240Vac, 1Φ+N+PE, 50/60Hz, 5.5A, 2500VA/1200W	12*2=24Vdc, 9.0AH*2 Battery box install inside UPS
3000VA	220-240Vac, 1Φ+N+PE, 50/60Hz, 10.0A	Output: 220-240Vac, 1Φ+N+PE, 50/60Hz, 5.5A, 3000VA/1200W	12*2=24Vdc, 9.0AH*2 Battery box install inside UPS



Most Technology Service Co., Limited

No. 5, 2nd Langshan Road, North District, Hi-tech Industrial Park,
Nanshan, Shenzhen, Guangdong, China

Tel: 86 755 86026850

Fax: 86 755 2601 3350

Http://www.szmost.com