

## DECLARATION OF CONFORMITY

*We,* **Cooper Fulleon Ltd,  
Llantarnam Park,  
Cwmbran, South Wales,  
United Kingdom.  
NP44 3AW**

*declare under our sole responsibility that the product(s)*

**Asserta Midi AV 9-60VDC**

**(Fire Alarm Device – Sounders for Fire Detection & Fire Alarm Systems)**

*Manufactured at the following site,*

**Cooper Fulleon Ltd, Llantarnam Park, Cwmbran, South Wales, United Kingdom.  
NP44 3AW**

*is (are) in conformity with the following standard(s) or other normative document(s)*

**EN 61000-6-3:2007 + A1: 2011, EN 50130-4:2011 (EMC)**

**EN 54-3:2001 + A1:2002 + A2:2006, BS IEC 60092-504:2001, BS IEC 60533:1999 (MED)**

**EN 50581:2012 (RoHS)**

*when used in the following applications & conditions:*

**Fire detection & Alarm Systems (Type A)**

*following the provisions of the directive(s):*

**2004/108/EC EMC**

**96/98/EC MED**

**27<sup>th</sup> May 2014**

*Date of Declaration*



**Chris Anderson, Technical Director  
Cooper Fulleon Limited**

Year of affixing the CE-marking: 2011